



中国认可
国际互认
检测
TESTING
CNAS L0699



TEST REPORT

CEPRI-EETC08-2017-0363

Client: Shanghai Chardon Electrical Ltd.

Object: 36kV 630A screened separable connector

Type: 36-FDT630/36-RDT630 1×185

Test Category: Type Tests



POWER INDUSTRY QUALITY INSPECTION AND TEST

CENTER FOR ELECTRIC EQUIPMENT

Catalogue

| | |
|---|----|
| 1. Catalogue..... | 1 |
| 2. Signature Page | 2 |
| 3. Test Results..... | 3 |
| 4. Content..... | 5 |
| 5. Appendix A Object Parameters..... | 8 |
| 6. Appendix B The Main Test Devices | 9 |
| 7. Appendix C Waveforms..... | 9 |
| 8. Appendix D Other Information | 13 |

| Test Report | | Power Industry Quality Inspection and Test Center for Electric Equipment | | CEPRI-EETC08-2017-0363 Total 15 Page 2 |
|--------------------|---|--|--------------|---|
| Client | Shanghai Chardon Electrical Ltd. | | Manufacturer | Shanghai Chardon Electrical Ltd. |
| Object | 36kV 630A screened separable connector | | Type | 36-FDT630/36-RDT630 1×185 |
| Sampling procedure | by the Client | | Serial No. | EETC08-17/05/31-004 |
| Test Category | Type Tests | | Date | 2017.06.12~2017.11.10 |
| Requirements | 1. GB/T 12706.4—2008 Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m=1.2$ kV) up to 35 kV ($U_m=40.5$ kV) — Part 4: Test requirements on accessories for cables with rated voltages from 6 kV ($U_m=7.2$ kV) up to 35 kV ($U_m=40.5$ kV) 2. IEC 60502-4:2010 Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m=1.2$ kV) up to 30 kV ($U_m=36$ kV) - Part 4: Test requirements on accessories for cables with rated voltages from 6 kV ($U_m=7.2$ kV) up to 30 kV ($U_m=36$ kV) | | | |
| Conclusion |  According to GB/T 12706.4—2008 and IEC 60502-4:2010, type tests were performed on 36kV 630A screened separable connectors which were provided by Shanghai Chardon Electrical Ltd. All the results were in accordance with the requirements. | | | |
| Note | / | | | |
| Compiled by: | 韩卫京 | | | |
| Checked by: | 彭超 | | | |
| Approved by: | 邬雄 | | | |
| | 付平 18年 | | | |
| | 苗付贵 | | | |
| | Date of issue: 2017. 11. 23. | | | |

Test Results

| No. | Item | Requirements | Results | | Evaluation |
|-----|---|--|---|------------|------------|
| 1 | Sequence 4.1 | / | / | | / |
| 1.1 | AC voltage test | No breakdown shall occur at 81 kV for 5 min | No breakdown occurred on the combination samples at 81 kV for 5 min | | passed |
| 1.2 | Partial discharge test at ambient temperature | The magnitude of the discharge at 30 kV shall not exceed 10 pC | Phase | No.1& No.4 | No.2& No.3 |
| | | | Voltage (kV) | 30 | 30 |
| | | | Noise background (pC) | 1.9 | 1.9 |
| | | | Discharge (pC) | 1.9 | 2.6 |
| 1.3 | Impulse voltage test at 95 °C~100 °C | No breakdown shall occur at 10 positive and 10 negative impulses of 170 kV | No breakdown occurred on the combination samples at 10 positive and 10 negative impulses of 170 kV (See Appendix C.1) | | passed |
| 1.4 | Heating cycle voltage test | No breakdown shall occur during 30 cycles in air and 30 cycles under water at the conductor temperature of 95°C to 100°C and 45 kV | No breakdown occurred on the combination samples 30 cycles in air and 30 cycles under water at the conductor temperature of 95°C to 100°C and 45 kV | | passed |
| 1.5 | Partial discharge test at ambient temperature | The magnitude of the discharge at 30 kV shall not exceed 10 pC | Phase | No.1& No.4 | No.2& No.3 |
| | | | Voltage (kV) | 30 | 30 |
| | | | Noise background (pC) | 2.0 | 2.0 |
| | | | Discharge (pC) | 2.0 | 3.0 |
| 1.6 | Partial discharge test at 95°C~100°C | The magnitude of the discharge at 30 kV shall not exceed 10 pC | Phase | No.1& No.4 | No.2& No.3 |
| | | | Voltage (kV) | 30 | 30 |
| | | | Noise background (pC) | 2.0 | 2.0 |
| | | | Discharge (pC) | 2.0 | 3.3 |

| Test Report | | Power Industry Quality Inspection and Test Center for Electric Equipment | | CEPRI-EETC08-2017-0363 Total 15 Page 4 |
|-------------|--|---|--|---|
| 1.7 | Impulse voltage test | No breakdown shall occur at 10 positive and 10 negative impulses of 170 kV | No breakdown occurred on the combination samples at 10 positive and 10 negative impulses of 170 kV (See Appendix C.2) | passed |
| 1.8 | AC voltage test | No breakdown shall occur at 45 kV for 15 min | No breakdown occurred on the combination samples at 45 kV for 15 min | passed |
| 1.9 | Examination | <p>It is advised that the accessory be examined for signs of any of the following:</p> <ul style="list-style-type: none"> (i) cracking in the filling media and/or tape or tube components; (ii) a moisture path across a primary seal; (iii) corrosion and/or tracking and/or erosion; (iv) leakage of an insulating material. | <ul style="list-style-type: none"> (i) No cracking in the filling media and tape or tube components; (ii) No moisture path across a primary seal; (iii) No evident corrosion, tracking and erosion; (iv) No leakage of an insulating material. | passed |
| 2 | Sequence 4.2 and 4.3 | / | / | / |
| 2.1 | AC voltage test | No breakdown shall occur at 81 kV for 5 min | No breakdown occurred on the combination samples at 81 kV for 5 min | passed |
| 2.2 | Thermal short-circuit test (conductor) | No visible deterioration at 24.2 kA, 2 s, twice | No visible deterioration at 24.73 kA, 2.01 s and 24.78 kA, 2.01 s (See Appendix C.4) | passed |
| 2.3 | Dynamic short-circuit test (conductor) | No visible deterioration at 85.4 kA, not less than 10 ms | No visible deterioration at 86.23 kA, 80 ms (See Appendix C.5) | passed |
| 2.4 | Impulse voltage test | No breakdown shall occur at 10 positive and 10 negative impulses of 170 kV | No breakdown occurred on the combination samples at 10 positive and 10 negative impulses of 170 kV (See Appendix C.3) | passed |

| Test Report | | Power Industry Quality Inspection and Test Center for Electric Equipment | | | CEPRI-EETC08-2017-0363 Total 15 Page 5 | | | |
|--|-------------------------|---|--|---------------|---|--------|--|--|
| 2.5 | AC voltage test | No breakdown shall occur at 45 kV for 15 min | No breakdown occurred on the combination samples at 45 kV for 15 min | | passed | | | |
| 2.6 | Examination | <p>It is advised that the accessory be examined for signs of any of the following:</p> <ul style="list-style-type: none"> (i) cracking in the filling media and/or tape or tube components; (ii) a moisture path across a primary seal; (iii) corrosion and/or tracking and/or erosion; (iv) leakage of an insulating material. | <ul style="list-style-type: none"> (i) No cracking in the filling media and tape or tube components; (ii) No moisture path across a primary seal; (iii) No evident corrosion, tracking and erosion; (iv) No leakage of an insulating material. | | passed | | | |
| 3 | Other items | / | / | | / | | | |
| 3.1 | Screen resistance tests | Screen resistance before and after the heating period shall not exceed 5000 Ω | type | before ageing | after ageing | | | |
| | | | 36-FDT630 | 502 Ω | 244 Ω | | | |
| 3.2 | Screen leakage current | Screen leakage shall not exceed 0.5 mA at 36 kV | Screen leakage didn't exceed 0.5 mA at 36 kV | | | passed | | |
| Content | | | | | | | | |
| 1. Sequence 4.1 in Table 7 of GB/T 12706.4—2008 | | | | | | | | |
| 1.1 AC voltage test | | | | | | | | |
| 1.1.1 Test method | | | | | | | | |
| The test shall be carried out in accordance with GB/T 18889—2002, clause 4. No breakdown shall occur at 81 kV for 5 min. | | | | | | | | |
| 1.2 Partial discharge test at ambient temperature | | | | | | | | |
| 1.2.1 Test method | | | | | | | | |
| The test voltage shall be raised gradually to and held at 36 kV for 10 s and then slowly reduced to 30 kV. The test shall be carried out in accordance with GB/T 18889—2002, clause 7. | | | | | | | | |

| Test Report | Power Industry Quality Inspection and Test Center for Electric Equipment | CEPRI-EETC08-2017-0363 Total 15 Page 6 |
|--|--|---|
| 1.3 Impulse voltage test at 95 °C~100 °C | | |
| 1.3.1 Test method | | |
| <p>The test shall be carried out in accordance with GB/T 18889—2002, clause 6. The conductor of the cable shall be heated and stabilized for at least 2 h at a temperature of 95 °C~100 °C. No breakdown shall occur at 10 positive and 10 negative impulses of 170 kV.</p> | | |
| 1.4 Heating cycle voltage test | | |
| 1.4.1 Test method | | |
| <p>The test shall be carried out in accordance with GB/T 18889—2002, clause 9. Each heating cycle shall be of at least 8 h duration with at least 2 h at a steady temperature of 5 °C to 10 °C above the maximum cable conductor temperature in normal operation, followed by at least 3 h of natural cooling to within 10 °C of ambient temperature. No breakdown shall occur 30 cycles in air and 30 cycles under water at the conductor temperature of 95°C to 100°C and 45 kV.</p> | | |
| 1.5 Partial discharge test at 95 °C~100 °C | | |
| 1.5.1 Test method | | |
| <p>The test voltage shall be raised gradually to and held at 36 kV for 10 s and then slowly reduced to 30 kV.</p> | | |
| <p>The test shall be carried out in accordance with GB/T 18889—2002, clause 7. The conductor temperature shall be of 95°C to 100°C during the test.</p> | | |
| 1.6 Partial discharge test at ambient temperature | | |
| 1.6.1 Test method | | |
| <p>The test voltage shall be raised gradually to and held at 36 kV for 10 s and then slowly reduced to 30 kV.</p> | | |
| <p>The test shall be carried out in accordance with GB/T 18889—2002, clause 7.</p> | | |
| 1.7 Impulse voltage test | | |
| 1.7.1 Test method | | |
| <p>The test shall be carried out in accordance with GB/T 18889—2002, clause 6. No breakdown shall occur at 10 positive and 10 negative impulses of 170 kV.</p> | | |
| 1.8 AC voltage test | | |
| 1.8.1 Test method | | |
| <p>The test shall be carried out in accordance with GB/T 18889—2002, clause 4. No breakdown shall occur at 45 kV for 15 min.</p> | | |
| 1.9 Examination | | |
| 1.9.1 Test method | | |
| <p>It is advised that the accessory be examined for signs of any of the following:(i) cracking in the filling media and/or tape or tube components;(ii) a moisture path across a primary seal;(iii) corrosion and/or tracking and/or erosion;(iv) leakage of an insulating material.</p> | | |
| 2. Sequence 4.2 and 4.3 in Table 7 of GB/T 12706.4—2008 | | |
| 2.1 AC voltage test | | |
| 2.1.1 Test method | | |
| <p>The test shall be carried out in accordance with GB/T 18889—2002, clause 4. No breakdown shall occur at 81 kV for 5 min.</p> | | |

| Test Report | Power Industry Quality Inspection and Test Center for Electric Equipment | CEPRI-EETC08-2017-0363 Total 15 Page 7 |
|---|--|---|
| 2.2 Thermal short-circuit test (conductor) | | |
| 2.2.1 Test method | | |
| The test shall be carried out in accordance with GB/T 18889—2002, clause 11. Two short-circuits shall be applied using AC to raise the conductor temperature to the maximum permissible short-circuit temperature(250°C) of the cable within 5 s. Between the two short-circuits, the test loop shall be allowed to cool to a temperature less than 10 °C above its temperature prior to the first short-circuit. There shall be no visible deterioration on the samples. | | |
| 2.3 Dynamic short-circuit test (conductor) | | |
| 2.3.1 Test method | | |
| The test shall be carried out in accordance with GB/T 18889—2002, clause 12. The dynamic short-circuit current value shall be 2.5 times of the thermal short-circuit value when the thermal short-circuit time equals 1s. There shall be no visible deterioration on the samples after the short-circuit lasts for at least 10s. | | |
| 2.4 Impulse voltage test | | |
| 2.4.1 Test method | | |
| The test shall be carried out in accordance with GB/T 18889—2002, clause 6. No breakdown shall occur at 10 positive and 10 negative impulses of 170 kV. | | |
| 2.5 AC voltage test | | |
| 2.5.1 Test method | | |
| The test shall be carried out in accordance with GB/T 18889—2002, clause 4. No breakdown shall occur at 45 kV for 15 min. | | |
| 2.6 Examination | | |
| 2.6.1 Test method | | |
| It is advised that the accessory be examined for signs of any of the following:(i) cracking in the filling media and/or tape or tube components;(ii) a moisture path across a primary seal;(iii) corrosion and/or tracking and/or erosion; (iv) leakage of an insulating material. | | |
| 3. Other items in Table 7 of GB/T 12706.4—2008 | | |
| 3.1 Screen resistance tests | | |
| 3.1.1 Test method | | |
| The test shall be carried out in accordance with GB/T 18889—2002, clause 14. Screen resistance before and after the heating period shall be measured at ambient temperature. According to clause 8.1 in GB/T 2951.2, the sample after the heating period shall be placed in the air oven at the temperature of $(120 \pm 2)^\circ\text{C}$ for 168 h. | | |
| 3.2 Screen leakage current | | |
| 3.2.1 Test method | | |
| The test shall be carried out in accordance with GB/T 18889—2002, clause 15. A metal foil of 25 cm^2 (namely $5\text{cm} \times 5\text{cm}$) shall be fixed to the outer shield of the separable connector as far as possible from the ground point (There shall be no air gap between the metal foil and the outer shield). The metal foil shall be grounded through a resistance of 2000Ω , and an AC voltage of 36kV shall be applied between the cable conductor of the combination samples and the ground to measure the leakage current. | | |

Appendix A Object Parameters

A.1 Sample information

The sample was received by Power Cable Station on 31/05/2017. The sample was in good condition with the date of manufacture not provided.

A.2 The number and installation of samples

According to GB/T 12706.4—2008, It was required that four sets of samples to be tested were installed by the manufacturer on eight length of cables forming No.1, No.2, No.3 and No.4 combination samples on which the type tests sequence 4.1, 4.2 and 4.3 were carried out. Eight sets of outdoor terminations were also installed by the manufacturer on the combination samples. The cable used in the combination samples was a XLPE insulated single-core cable for rated voltage 18/30 kV, a cross-section of 185 sq.mm. The length of the cable in the combination sample was greater than 5 m between terminations and the samples. Other type tests listed in table 7 were carried out on other samples.

A.3 Photograph of samples



A.4 Photograph of dissected samples



| Test Report | | Power Industry Quality Inspection and Test Center for Electric Equipment | | | | | CEPRI-EETC08-2017-0363 Total 15 Page 9 | |
|----------------------------------|---|--|-------------------|--|---|--|---|--|
| Appendix B The Main Test Devices | | | | | | | | |
| No. | Name/ Type/ Specification | Serial No. | Measurement Range | Uncertainty / Accuracy class / Maximum Permissible Error | Calibration Institute | | Valid Date | |
| 1 | TRF300-0.002 AC voltage measurement system | 110650 | (0~300) kV | Grade 3 | National high voltage measurement station | | 2018.07.21 | |
| 2 | JFD-2H PD measurement system | 20041202 | (0.5~1000) pC | Class 10 | National high voltage measurement station | | 2018.05.19 | |
| 3 | FY I 900/600 Weakly damped capacitive voltage divider | 11165-2-1 | (0~900) kV | Class 3 | National high voltage measurement station | | 2018.06.29 | |
| 4 | H-DJF-2 Data collected system | CJ06 | (0~100) kA | Class 0.5 | National high voltage measurement station | | 2020.01.03 | |
| 5 | LM-0.5 Current transformer | 3306 | (0~3000) A | Class 0.5 | National high voltage measurement station | | 2020.10.26 | |
| 6 | MAS- II digital microammeter | 20001 | (0~2000) uA | Class 1.5 | Vkan Certification & Testing Co., Ltd. Measuring Center | | 2018.10.16 | |
| 7 | 287C Digital voltage meter | 31470016 | (0~700) V | Class 1 | Vkan Certification & Testing Co., Ltd. Measuring Center | | 2018.07.02 | |

Appendix C Waveforms

C.1 The values and waveforms of impulse voltage on the combination samples before heating cycles voltage test

C.1.1 The values of impulse voltage test





Ambient temperature: 30°C

Relative humidity: 72%

Atmosphere: 0.1012MPa

| | | | | | | | | | | |
|------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Positive polarity (kV) | 172 | 171 | 171 | 172 | 170 | 171 | 171 | 171 | 172 | 172 |
| Negative polarity (kV) | 171 | 170 | 170 | 171 | 171 | 172 | 170 | 169 | 171 | 168 |

C.1.2 The waveforms of impulse voltage test

The 1st positive impulses waveformThe 10th positive impulses waveformThe 1st negative impulses waveformThe 10th negative impulses waveform

C.2 The values and waveforms of impulse voltage on the combination samples after heating cycles voltage test

C.2.1 The values of impulse voltage test



Ambient temperature: 17.0°C



Relative humidity: 61%

Atmosphere: 0.1018MPa

| | | | | | | | | | | |
|------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Positive polarity (kV) | 172 | 171 | 171 | 172 | 172 | 172 | 172 | 170 | 171 | 171 |
| Negative polarity (kV) | 172 | 172 | 171 | 171 | 172 | 171 | 172 | 171 | 172 | 170 |

C.2.2 The waveforms of impulse voltage test

The 1st positive impulses waveformThe 10th positive impulses waveform

The 1st negative impulses waveformThe 10th negative impulses waveform

C.3 The values and waveforms of impulse voltage on the combination samples after thermal and dynamic short-circuit tests

C.3.1 The values of impulse voltage test





Ambient temperature: 19.0°C

Relative humidity: 63%

Atmosphere: 0.1019MPa

| | | | | | | | | | | |
|------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Positive polarity (kV) | 173 | 172 | 171 | 172 | 172 | 172 | 173 | 171 | 172 | 173 |
| Negative polarity (kV) | 168 | 172 | 171 | 172 | 172 | 173 | 172 | 171 | 172 | 171 |

C.3.2 The waveforms of impulse voltage test

The 1st positive impulses waveformThe 10th positive impulses waveformThe 1st negative impulses waveformThe 10th negative impulses waveform

Appendix D Other Information**D.1 Identification of test cable (specified in GB/T 12706.2—2008)**

| | | |
|----------------------------|------------------------------------|------------------------|
| rated voltage $U_0/U(U_m)$ | | 18/30(36) kV |
| construction | core | single-core |
| | construction of screen | single phase screen |
| conductor | material | copper |
| | type | round compact stranded |
| insulation | cross section | 185 mm ² |
| | diameter | 16.2 mm |
| | material | XLPE |
| screen | thickness | 8.0 mm |
| | diameter | 34.3 mm |
| | thickness of conductor screen | 0.9 mm |
| armour | thickness of insulation screen | 0.9 mm |
| | strippability of insulation screen | strippable |
| | diameter of insulation screen | 36.1 mm |
| oversheath | metallic screen | copper tape |
| | material | PVC |
| | diameter | 43.0mm |
| mark of cable | | YJV-18/30 1×185 |

