



中国认可
国际互认
检测
TESTING
CNAS L0699



TEST REPORT

CEPRI-EETC02-2017-0090

Client: Shanghai Chardon Electric Ltd.

Object: Separable Connectors 26kV/72kV Coupling
(Rear)T-Body Surge Arrester

Type: 26-RDTA72-10






Test Category: Type Test



POWER INDUSTRY QUALITY INSPECTION AND TEST
CENTER FOR ELECTRIC EQUIPMENT

Catalogue

1.Catalogue	1
2.Signature Page	2
3.Test Results	3
4.Content	4
5.Appendix A Object Parameters	12
6.Appendix B The Main Test Devices	12
7.Appendix C Waveforms	13
8.Appendix D Visual and dimensional check.....	16

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2017-0090 Total 17 Page 2
Client	Shanghai Chardon electric Ltd.	Manufacturer	Shanghai Chardon electric Ltd.
Object	Separable Connectors 26kV/72kV Coupling (Rear) T-Body Surge Arrester	Type	26-RDTA72-10 (Φ42mm×24mm)
Sampling procedure	By the client delivery	Serial No.	3 arresters (001~003) 6 thermally prorated sections (201~206) 9 resistors (301~309) 3 housings(401~403)
Test Category	Type Test	Date	2018.01.24~2018.04.12
Requirements	GB/T 11032-2010 Metal-oxide surge arresters without gaps for a.c. systems		
Conclusion	The Separable connectors 26kV/72kV coupling(rear)T-body surge arrester without gaps for 20kV a.c. systems of 26-RDTA72-10 have successfully passed the type test specified in GB/T 11032-2010.		
Note	<p>Note 1: In the event of any difference in meanings of the text, the Chinese report shall take precedence over the English version.</p> <p>Note 2: Since the date of issuance, the routine test which concerns about the related content must be done every three years in order to extend the validity of this report.</p>		
<p>Compiled by: 黄佳瑞  梁菊霞 </p>			
<p>Checked by: 左中秋  Verified by: 熊易 </p>			
<p>Approved by: 王保山  Date of issue: 2018.06.06</p>			

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2017-0090 Total 17 Page 3
-------------	--	---

Test Results

No.	Item	Requirements	Results	Evaluation	
1	D.C. reference voltage test	$37.0\text{kV} \leq U_{1\text{mA,DC}} \leq 39.0\text{kV}$	37.6kV~37.7kV	Passed	
2	Leakage current test at 0.75 times D.C. reference voltage	$I_l(0.75U_{1\text{mA,DC}}) \leq 50\mu\text{A}$	2 μA ~3 μA	Passed	
3	Continuous operating current test	$I_x \leq 400\mu\text{A}$ $I_R \leq 100\mu\text{A}$	$I_x = 126\mu\text{A} \sim 131\mu\text{A}$ $I_R = 20\mu\text{A} \sim 27\mu\text{A}$	Passed	
4	A.C. reference voltage test	$U_{1\text{mA,AC}} \geq 26.0\text{kV}$	30.8kV~31.7kV	Passed	
5	Partial discharge test	$1.05U_c$ 下, $PD \leq 10\text{pC}$	$PD = 1.0\text{pC} \sim 2.0\text{pC}$	Passed	
6	Seal leak rate test	Put the samples into the boiling water with 0.1%NaCl for 42 h: change rate of $U_{1\text{mA,DC}} \leq 5\%$ change of leakage current $I_l \leq 20\mu\text{A}$ partial discharge $PD \leq 10\text{pC}$	$\Delta U_{1\text{mA,DC}} = -0.27\% \sim 0\%$ $\Delta I_l = -3\mu\text{A} \sim +4\mu\text{A}$ $PD = 1.0\text{pC} \sim 3.0\text{pC}$	Passed	
7	Bending moment	Bending load $\geq 390.76\text{N}$ for 60s~90s, and meet the evaluation requirements.	400N, 60s	Passed	
8	Insulation withstand tests on the arrester housing	Power-frequency voltage: Dry $\geq 54\text{kV}$, for 1min. Lightning impulse voltage : 125kV _p , the positive and negative 15 times respectively.	Power-frequency voltage (dry) 54.19 kV~54.41kV, 1min. Lightning impulse voltage 128.9kV _p ~134.8kV _p , the positive and negative 15 times respectively.	Passed	
9	Residual voltage test	Lightning impulse current	$\leq 72.0\text{kV}_p$	69.21kV _p	Passed
		Steep impulse current	$\leq 65.0\text{kV}_p$	53.51kV _p	
		Switching impulse current	$\leq 85.0\text{kV}_p$	77.40kV _p	
10	Long duration current impulse withstand test	2000 μs 、350A、18times	2008 μs 、350A~370A	Passed	
11	Operating duty test	115 $^{\circ}\text{C}$ 、1000h	$P_{2et} < 1.1 P_{3et}$ and $P_{2et} < P_{1et}$	Passed	
		4/10 μs 、100kA high-current impulse, 2 times	95.6kA~100.3kA		
12	Power-frequency voltage versus time characteristics test	Supply the Power-frequency voltage versus time characteristics for the range of voltage from 1.10U _R * to 0.85U _R *, the range of time from 10s to 24h: for 1.10 U _R *, the time is 10s; for 0.85 U _R *, the time is 24h.	1.10U _R * 10s 1.00U _R * 2h 0.85U _R * 24h	Passed	

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2017-0090 Total 17 Page 4
-------------	--	---

Content:

1~2 D.C. reference voltage test and leakage current at 0.75 times D.C. reference voltage test

Environment temperature: 21.5℃ humidity: 53%

Samples	D.C. reference voltage $U_{1mA,DC}$ kV		0.75times D.C. reference voltage kV		Leakage current μA	
	Measured value	Specified value	Measured value	Specified value	Measured value	Specified value
001	37.7	$37.0 \leq U_{1mA,DC} \leq 39.0$	28.3	$0.75U_{1mA,DC} \pm 1\%$	2	≤ 50
002	37.6		28.2		2	
003	37.6		28.2		3	

Note: The standard only provides the D.C. reference voltage lower limit. The upper limit declared by the manufacturer is used to determine the proportion of the arrester protection level.

Fulfilled the requirements.

3~4 Power-frequency reference voltage test and Continuous current test

Environment temperature: 21.5℃ humidity: 53%

Samples	The power-frequency reference voltage U_{1mAAC} kV (Peak value / $\sqrt{2}$)		I_R μA_T		I_X μA_{rms}	
	Measured value	Specified value	Measured value	Specified value	Measured value	Specified value
001	31.4	≥ 26.0	20	≤ 100	126	≤ 400
002	30.8		22		131	
003	31.7		27		129	

Note1: The client claims the power frequency reference current is 1mA.

Note2: The standard specifies the continuous current through the arrester shall not exceed the manufacturer's declared value.

Fulfilled the requirements.

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2017-0090 Total 17 Page 5
-------------	--	---

5 Partial discharge test

Samples	U_r	U_r duration time	$1.05U_r$	$1.05U_r$ duration time	partial discharge
	kV_{rms}	s	kV_{rms}	s	pC
001	26	10	21.8	60	1.0
002	26	10	21.8	60	2.0
003	26	10	21.8	60	2.0
specified value	26	2~10	21.6	60	≤ 10

Fulfilled the requirements.

6 Seal leak rate test

Samples	Boiling time	Cooling time	DC reference voltage			leakage current at $0.75U_{1mA,DC}$			Partial discharge		Surface check after test
			Before	After	change rate	Before	After	change rate	Before	After	
			h	kV	%	μA	pC				
001	42	5	37.7	37.7	0	2	5	+3	1.0	1.0	No visible mechanical damage
002	42	5	37.6	37.5	-0.27	2	5	+3	2.0	3.0	No visible mechanical damage
003	42	5	37.6	37.6	0	3	7	+4	2.0	2.0	No visible mechanical damage
specified value	42	≤ 8	≥ 37.0	≤ 5	≤ 50	≤ 20	≤ 10				Should not have visible mechanical damage

Note 1: NaCl concentration in water for 1 kg/m³.

Fulfilled the requirements.

7 Bending moment

7.1 The test of bending moment

$$F_1=147N \quad S=0.031m^2 \quad F_2=18.61N$$

$$\text{The test load MPSSL} = 2.5 \times (F_1 + F_2 / 2) = 390.76N$$

Sample	Actual loading	Time	Max deflection	Residual deflection	Housing height	deflection rate	force / deflection curve	Sample check
	N	s	mm	mm	mm	%	-	-
001	400	60	10.7	3.4	349	0.97	no mutation	No mechanical damage
specified value	390.76	60~90	/	/	/	≤ 5	Should not have mutation	Should not have mechanical damage

7.2 The parameters comparison before and after test

Sample	$U_{1mA,DC}$			leakage current			Partial discharge	
	kV			μA			pC	
	Before	After	change rate %	Before	After	change rate	Before	After
001	37.7	37.7	0	2	5	+3	1.0	1.0
specified value	≥ 37		≤ 5	≤ 50		≤ 20	≤ 10	

Fulfilled the requirements.

8 Housing insulation withstand test

8.1 Power frequency voltage withstand test

$t_d=24.5^{\circ}C$ $t_w=19.5^{\circ}C$ Atmospheric pressure: 100.2kPa
Applicable altitude: $\leq 1000m$

Samples	Specified value	Atmospheric correction factor	Altitude correction factor	Applied voltage	Correction value	Duration	Test result
	kV	K_1	K_2	kV(Peak value $/\sqrt{2}$)	kV(Peak value $/\sqrt{2}$)		
401	54(dry)	1.000	1.000	54	54.41	60	No flashover
402	54(dry)	1.000	1.000	54	54.19	60	No flashover
403	54(dry)	1.000	1.000	54	54.23	60	No flashover

Fulfilled the requirements.

8.2 Lightning impulse voltage withstand test

$t_d=23.5^{\circ}C$ $t_w=20.5^{\circ}C$ Atmospheric pressure: 100.2kPa
Applicable altitude: $\leq 1000m$

Samples	Specified value		Atmospheric correction factor	Altitude correction factor	Applied voltage	Correction value	With stand times	Test result
	(+)	(-)	K_1	K_2	kV _p	kV _p		
401~403	(+)	125	1.000	1.000	127.6~134.8	127.6~134.8	15	No breakdown, no flashover
	(-)	125	1.000	1.000	128.9~134.7	128.9~134.7	15	No breakdown, no flashover

Fulfilled the requirements, test waveform is shown in figure C.1.

9 Residual voltage test

9.1 Lightning impulse current residual voltage test

Samples			301	302	303
resistor	U_{ImADC}	kV	5.39	5.33	5.43
	8/20 μ s, 5kA	kV _p	8.78	8.61	8.74
	8/20 μ s, 10kA	kV _p	9.56	9.40	9.51
	8/20 μ s, 20kA	kV _p	10.55	10.39	10.58
	U_{10kA}/U_{ImADC}	-	1.77	1.76	1.75
Complete arrester	U_{ImADC}	kV	$37.0 \leq U_{ImADC} \leq 39.0$		
	Scale coefficient	-	7.24	7.32	7.18
	Lightning impulse protection level	kV _p	69.21		
	Specified value	kV _p	≤ 72.0		

Note 1: Shunt $R_s=0.025\Omega$, divider $K_d=206.1$

Note 2: According to the determined residual pressure, draw the residual voltage and current curve, in the curve corresponding to the nominal discharge current read residual voltage, defined as the lightning protection lightning protection level.

9.2 Switching impulse current residual voltage test

Samples			301	302	303
resistor	Residual voltage at 500A	kV _p	7.50	7.31	7.47
Complete arrester	Scale coefficient	-	7.24	7.32	7.18
	Test value	kV _p	54.30	53.51	53.63
	Specified value	kV _p	≤ 65.0		

Note 1: Shunt $R_s=0.025\Omega$, divider $K_d=206.1$

9.3 Steep impulse current residual voltage test

Samples			301	302	303
resistor	10 kA U_{res1}	kV _p	10.69	10.53	10.66
	10 kA U_{res2}	kV _p	0.25		
	U_{res2}/U_{res1}	%	2.34	2.37	2.35
	$U_{res1}-U_{res2}$	kV _p	10.44	10.28	10.41
Complete arrester	Scale coefficient	-	7.24	7.32	7.18
	Residual voltage for the arrester	kV _p	75.59	75.25	74.74
	Inductance per unit length	μ H/m	1		
	Height without resistors	m	$0.349-(0.024 \times 7)=0.181$		
	Inductive voltage correction	kV _p	$1 \times 0.181 \times 10=1.81$		
	Residual voltage for the arrester after correction	kV _p	77.40	77.06	76.55
	Specified value	kV _p	≤ 85.0		

Note 1: Shunt $R_s=0.025\Omega$, divider $K_d=67.8$

Note 2: If U_{res2}/U_{res1} is less than 2%, there is no need to correct inductive effect.

Fulfilled the requirements. Test waveform is shown in figure C.2 ~ figure C.4.

Test Report		Power Industry Quality Inspection and Test Center for Electric Equipment			CEPRI-EETC02-2017-0090 Total 17 Page 8	
10 Rectangular current impulse withstand test						
Temperature of the environment: 15.5℃ humidity: 70%						
Samples		304	305	306	Specified value	
8/20 μ s I_0 residual voltage before test	kV _p	9.43	9.41	9.48	/	
Virtual duration of the peak of a rectangular impulse $T_{0.9}$	μ s	2008			2000 μ s (100%~120%)	
Virtual total duration of a rectangular impulse $T_{0.1}$	μ s	2644			$\leq 1.5T_{0.9}$	
Actual current value	The 1 st impulse	A	350	362	354	350A(90%~110%)
	The 2 nd impulse	A	352	360	350	
	The 3 rd impulse	A	354	360	350	
	The 4 th impulse	A	360	366	356	
	The 5 th impulse	A	358	366	354	
	The 6 th impulse	A	358	364	354	
	The 7 th impulse	A	358	366	354	
	The 8 th impulse	A	356	366	356	
	The 9 th impulse	A	354	364	352	
	The 10 th impulse	A	364	370	356	
	The 11 th impulse	A	360	366	356	
	The 12 th impulse	A	360	364	354	
	The 13 th impulse	A	358	368	354	
	The 14 th impulse	A	358	368	354	
	The 15 th impulse	A	358	368	354	
	The 16 th impulse	A	358	368	356	
	The 17 th impulse	A	360	364	352	
	The 18 th impulse	A	358	364	354	
8/20 μ s I_0 residual voltage after test	kV _p	9.58	9.45	9.41	/	
Change rate	%	+1.59	+0.43	-0.74	≤ 5	
Test results	No breakdown, no flashover, No damage.				No breakdown, no flashover, no damage.	
Note: shunt $R_c=0.01V/A$.						
Fulfilled the requirements. Test waveform is shown in figure C.5						

11 Operating duty test

11.1 Accelerated ageing test

Items	Unit	Samples		
		307	308	309
U_{1mADC}	kV	5.44	5.43	5.42
applying power frequency	$kV_{r.m.s}$	3.27	3.26	3.26
chargeability	%	85.0	84.9	85.0
Power loss at 2 hours / P_{1et}	W	1.350	1.427	1.146
Power loss at 1008 hours / P_{2et}	W	1.020	1.054	1.016
Minimum power loss P_{3et}	W	1.020	1.054	0.983
$P_{2et} / 1.1P_{3et}$	-	0.91	0.91	0.94
P_{2et} / P_{1et}	-	0.76	0.74	0.89

Note1: Because $P_{2et} < 1.1P_{3et}$ and $P_{2et} < P_{1et}$, the samples of thermally treated sections which made of new resistors without aging and apply voltage would be U_{1e} and U_{2e} in operating duty test.

Note 2: Resistor temperature: $\Phi 15 \pm 4^\circ C$.




Figure1 Accelerated ageing test curve

11.2 Sample parameters for operating duty test

Samples		201	202	203
DC reference voltage U_{1mADC}	kV	5.42	5.41	5.41
Rated voltage U_r	$kV_{r.m.s}$	3.84	3.83	3.83
Continuous operating voltage U_c	$kV_{r.m.s}$	3.07	3.07	3.07
Aging ratio K_{et}	-	1.00	1.00	1.00
Rated voltage U_r^*	$kV_{r.m.s}$	3.84	3.83	3.83
Continuous operating voltage U_c^*	$kV_{r.m.s}$	3.07	3.07	3.07
1.20 times U_c^*	$kV_{r.m.s}$	3.68	3.68	3.68

11.3 Operating duty test

Temperature of the environment: 23.0°C humidity: 85%

Samples			201	202	203	Req.
8/20μs	U_{10kA} before	kV _p	9.48	9.50	9.46	/
Condition -ing test	Applying 1.20 U_c^*	kV _{r.m.s}	3.68	3.68	3.68	Applying 1.20 U_c^*
	Trigger Angle	°	54.0			Before the peak power frequency voltage 60°±15°
	The 1 st group	kA	9.91~10.09	9.89~10.03	9.94~10.07	Apply 20 times 8/20 nominal discharge current, each group of five times, a total of four groups
	The 2 nd group		9.89~10.11	9.91~10.05	9.95~10.12	
	The 3 rd group		9.92~10.12	9.92~10.12	9.94~10.09	
The 4 th group	9.95~10.07		9.95~10.07	9.91~10.12		
high current impulse	The 1 st time	kA	95.6	98.9	100.2	Apply 2 times 100 kA high current, cooled to ambient temperature between two impulse
	The 2 nd time	kA	97.8	99.7	100.3	
Applied voltage after 2 nd impulse	Time	ms	89	87	86	≤100
	U_r^*	kV _{r.m.s}	3.84	3.83	3.83	peak / $\sqrt{2}$
	Duration	s	10	10	10	10
	U_c^*	kV _{r.m.s}	3.07	3.07	3.07	-
	Duration	min	30	30	30	30
Power loss within 30 min	0min	W	3.47	3.39	3.41	In the last 15 min power loss should reduce Steadily
	5min		2.39	2.25	2.28	
	10min		1.56	1.43	1.41	
	15min		1.06	1.03	1.09	
	20min		0.92	0.89	0.91	
	25min		0.83	0.76	0.84	
	30min		0.79	0.71	0.77	
8/20μs	U_{10kA} after	kV _p	9.51	9.55	9.49	-
8/20μs	U_{10kA} change rate	%	+0.32	+0.53	+0.32	≤5
Visual inspection			No puncture, flashover, cracking or other significant damage			No puncture, flashover, cracking or other significant damage

Fulfilled the requirements. Test waveform is shown in figure C.6~C.8.

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2017-0090 Total 17 Page 11
-------------	--	--

12 Power frequency voltage-versus-time characteristic test

12.1 Sample parameters for power frequency voltage-versus-time characteristic test

Samples		204	205	206
DC reference voltage U_{limADC}	kV	5.39	5.41	5.41
Rated voltage U_r	kV_{rms}	3.81	3.83	3.83
Continuous operating voltage U_c	kV_{rms}	3.05	3.07	3.07
Aging ratio K_{at}	-	1.00	1.00	1.00
Rated voltage U_r^*	kV_{rms}	3.81	3.83	3.83
Continuous operating voltage U_c^*	kV_{rms}	3.05	3.07	3.07

12.2 Power frequency voltage-versus-time characteristic test

Temperature of the environment: 23.0°C humidity: 85%

Samples			204	205	206	Req.
8/20 μ s U_{10kA} before	kV		9.41	9.48	9.41	/
High-current impulse	kA		98.9	100.1	100.5	preheated samples to 60°C±3°C
Applied voltage after high-current impulse	Time	ms	89	89	87	≤100
	U_r^*	kV_{rms}	3.24	3.83	4.21	peak / $\sqrt{2}$
high-current impulse	Times of U_r^*	-	0.85	1.00	1.10	-
	Duration	-	24 h	2 h	10 s	-
	U_c^*	kV_{rms}	3.05	3.07	3.07	-
	Duration	min	30	30	30	30
Power loss within 30 min	0min		2.79	3.57	3.96	In the last 15 min power loss should reduce Steadily
	5min		2.13	2.85	3.17	
	10min		1.67	2.21	2.62	
	15min	W	1.19	1.73	2.07	
	20min		1.03	1.25	1.79	
	25min		0.88	1.04	1.55	
	30min		0.79	0.89	1.32	
8/20 μ s U_{10kA} after	kV_p		9.43	9.53	9.46	-
8/20 μ s U_{10kA} change rate	%		+0.21	+0.53	+0.53	≤5
Visual inspection			No puncture, flashover, cracking or other significant damage			No puncture, flashover, cracking or other significant damage
Fulfilled the requirements.						

Appendix A: Object ParametersRated voltage U_T : 26kVContinuous operating voltage U_C : 20.8kV_{r.m.s}Nominal discharge current I_n : 10kALightning impulse residual voltage: U_{res} : $\leq 72kV_P$

Sample description:

①3 Arresters, number EETC02-170227-0090-001-EETC02-170227-0090-003, short for 001-003 in report; ②6 thermally prorated sections, number EETC02-170227-0090-201-EETC02-170227-0090-206, short for 201-206 in report; ③9 resistors, number EETC02-170227-0090-301-EETC02-170227-0090-309, short for 301-309 in report; ④3 housings, number EETC02-170227-0090-401-EETC02-170227-0090-403, short for 401-403 in report.

Appendix B: Main test device

NO.	Device name	Device NO.	Measurement	Uncertainty /Accuracy	Calibration institution	Expiration date
1	Long duration (rectangular) current impulse generator	EETC02-0002	2ms 1 kA, 20kV	$U_{rel}=0.0056 k=2$ $U_{rel}=0.0064 k=2$	National center for high voltage measurement	2018-06-04
2	impulse current generator	EETC02-0003	8/20 μ s 100 kA, 20kV 4/10 μ s 150 kA, 20kV 30/80 μ s 50 kA, 20kV	$U_{rel}=0.0056 k=2$ $U_{rel}=0.0064 k=2$	National center for high voltage measurement	2018-06-04
3	Steep impulse wave current generator	EETC02-0004	1/5 μ s 20kA, 20kV	$U_{rel}=0.0056 k=2$ $U_{rel}=0.0064 k=2$	National center for high voltage measurement	2018-06-04
4	impulse current generator	EETC02-0005	8/20 μ s 50 kA, 20kV 30/80 μ s 10 kA, 20kV	$U_{rel}=0.0056 k=2$ $U_{rel}=0.0064 k=2$	National center for high voltage measurement	2018-06-04
5	800kV impulse voltage generator	EETC02-0007	0-800 kV	$U_{rel}=0.018 k=2$	National center for high voltage measurement	2018-08-09
6	400kV DC high voltage generator	EETC02-0008	0-400 kV	$U_{rel}=0.012 k=2$	National center for high voltage measurement	2018-06-06
7	300kV AC High Voltage generator	EETC02-0011	0-300 kV	/	/	/
	Digital high-voltage table	EETC02-0077	0-300 kV	1%	National center for high voltage measurement	2018-09-23
8	JFD-251 PD tester	EETC02-0043	/	0.5pC	National center for high voltage measurement	2018-06-06

Appendix C: Waveforms



Fig.C.1 Lightning impulse voltage withstand test samples 401-403




图 C.2 Lightning impulse current and residual voltage waveform (sample 301, shunt $R_s=0.025V/A$, divider $K_d=206.1$)



图 C.3 Switching impulse current and residual voltage waveform (sample 302, shunt $R_s=0.025V/A$, divider $K_d=206.1$)




图 C.4 Steep impulse current and residual voltage waveform (sample 302, shunt $R_s=0.025V/A$, divider $K_d=61.8$)




图 C.5 Rectangular impulse current waveform (sample 304, NO.1, shunt $R_s=0.01V/A$)




图 C.6 Preliminary test waveform (sample 201, transformer ratio $K_d=1540$)




图 C.7 High impulse current waveform (sample 201, shunt $R_s=0.001V/A$)




图 8.8 Operating duty test waveform (sample 201, divider K=1540)

(No content in this page below)

EETC

Appendix D: Visual and dimensional check



Fig.D1 26-RDTA72-10 arrester and resistor




Fig D2 : Dimensional drawing of 26-RDTA72-10