

# 25kV 200A Deadbreak Elbow Connector Design Test Report

---

Report Number:

Test Start Date:

Test Complete Date:

RN-R7607

2014 / 10 / 09

2015 / 10 / 15

---

Chardon Taiwan  
No. 37 Min-Chie Road  
Tung Lo Industrial Park  
Miao Li, Taiwan 366

## Table of Contents

1. Partial Discharge - Deadbreak Elbow .....	2
2. AC Withstand Voltage Test - Deadbreak Elbow .....	3
3. DC Withstand Voltage Test – Deadbreak Elbow .....	4
4. Impulse Withstand Testing – Deadbreak Elbow .....	6
5. Short-time Current Testing – Deadbreak Elbow .....	8
6. Cable Pull-Out Test Deadbreak Elbow .....	11
7. Operating Force Test Deadbreak Elbow .....	13
8. Operating Eye Test - Deadbreak Elbow .....	16
9. Test Point Cap Test - Deadbreak Elbow .....	17
10. Test Point Test - Deadbreak Elbow .....	19
11. Test Point Voltage Test - Deadbreak Elbow .....	20
12. Shielding Test - Deadbreak Elbow .....	21
13. Current Cycling – Accelerated Thermal Test .....	24
14. Accelerated Sealing Life Test.....	33
15. Current-cycling test – Thermal test with off-axis Operation	37
APPENDIX -External Test Report .....	41










Fig 3-1 DC Withstand Voltage Test Setup




Fig 3-2 DC Withstand Voltage Test in Progress






Impulse Withstand – Positive Wave




Impulse Withstand Testing – Negative Wave









A11&A12 10kA/0.17sec



A13&A14 10kA/0.18sec



A1&A2 3.5kA/3.04sec



B1&B2 3.5kA/3.02sec





Fig 6-1 Test in Progress




Fig 6-2 Pull Force Diagram

## 7. Operating Force Test Deadbreak Elbow

### Object

To verify the force of the elbow connector operating force when mating with bushing that the force meets NSI/IEEE Standard 386-2006 operating force requirement.

### Testing Samples

Deadbreak Elbow	25-DE200TC06B	4 PCS
-----------------	---------------	-------

### Mating Parts

Deadbreak Bushing	25kV 200A
Elbow Test Rod	25kV#C Testing Rod $\Phi$ 22.30mm

### Procedure

The purpose of this test is to demonstrate that the force necessary to operate a connector meets the requirements of 6.2.( 44 N - 890 N (10 lbf - 200 lbf) for connectors with hold-down bails)

The elbow shall be assembled with a probe and compression lug and the connector system shall be lubricated in accordance with the manufacturer's instructions.

**Results**

	Sample number	Open	Close	Result
Room Temperature  27°C	A11	16 lbf	116 lbf	PASS
	A12	17 lbf	120 lbf	PASS
	A13	17 lbf	133 lbf	PASS
	A14	18 lbf	128 lbf	PASS

-20 °C	A11	17 lbf	120 lbf	PASS
	A12	17 lbf	129 lbf	PASS
	A13	18 lbf	132 lbf	PASS
	A14	19 lbf	131 lbf	PASS

65 °C	A11	16 lbf	114 lbf	PASS
	A12	16 lbf	117 lbf	PASS
	A13	17 lbf	128 lbf	PASS
	A14	17 lbf	125 lbf	PASS





Fig 7-1 Test Setup



Fig 7-2 Testing in Progress





## 9. Test Point Cap Test - Deadbreak Elbow

### Object

To verify the test point cap of the elbow that the part meets ANSI/IEEE Standard 386-2006 requirement.

### Testing Samples

Deadbreak Elbow	25-DE200TC06B	4 PCS
Test Point Cap		4 PCS
Testing Fixture		

### Procedure and Testing Spec

The purpose of this test is to demonstrate that the removal force of the test point cap meets the requirements of 6.5.2 and the cap operating eye is capable of withstanding the maximum operating force

**Results**

	Sample number	Pull Force (8 lbf – 49 lbf)	100 lbf Pulling	Result
Room Temperature  27°C	A11	19.80 lbf	PASS	PASS
	A12	24.64 lbf	PASS	PASS
	A13	20.68 lbf	PASS	PASS
	A14	25.08 lbf	PASS	PASS

-20 °C	A11	22.43 lbf	PASS	PASS
	A12	25.33 lbf	PASS	PASS
	A13	23.47 lbf	PASS	PASS
	A14	27.56 lbf	PASS	PASS

65 °C	A11	19.65 lbf	PASS	PASS
	A12	22.38 lbf	PASS	PASS
	A13	20.22 lbf	PASS	PASS
	A14	24.71 lbf	PASS	PASS







Temperature	Sample number	5000 $\Omega$ max	Result
27 °C (Air oven aged for 504 h at 121 °C)	A11	1144 $\Omega$	PASS
	A12	1208 $\Omega$	PASS
	A13	1232 $\Omega$	PASS
	A14	1159 $\Omega$	PASS

Temperature	Sample number	5000 $\Omega$ max	Result
28 °C (Air oven aged for 504 h at 121 °C)	A11	1215 $\Omega$	PASS
	A12	1371 $\Omega$	PASS
	A13	1582 $\Omega$	PASS
	A14	1296 $\Omega$	PASS

2. *Fault-Current Initiation:* The outer conductive layers of deadbreak elbow are using the same material with Chardon 25kV Loadbreak Elbow. 2 Chardon Loadbreak Elbows samples successfully initiate two consecutive fault-current arcs to ground in the test performed in Powertech Labs, Surrey, B.C., Canada. All 2 samples passed. Powertech Test Report № PL-26015B. See APPENDIX.



Fig 12-1 Testing in Progress



Fig 12-2 Test Readings



### 13. Current Cycling – Accelerated Thermal Test

#### Object

The purpose of this accelerated test is to demonstrate that 200 A insulated connectors can carry rated current under usual service conditions. Successful completion of the test shall be considered as evidence that the connector meets its rating.

#### Testing Samples and Mating Parts

Elbow	CHARDON 25-DE200T	4 PCS
Bushing	CHARDON 24-DIB250	4 PCS

#### Mating Parts

Cable Conductor Type	1/0 AWG(Aluminum)
Cable Insulation Thickness	220 mil
Conductor	200A Bi-Metal Lug
Equalizers	Aluminum Equalizers Size : 106mm(L)20mm(OD)10.1mm(ID)
Bushing Bus	356mm(L), 102mm(W),10mm(T)

#### Testing Spec

A control cable, used for the purpose of obtaining conductor temperature, shall be installed in the heat cycle loop between two equalizers. Its length shall be 183 cm (72 in). The control cable shall be the same type and size as the cable used to join the connectors under test.

Four connectors shall be assembled in series on AWG No 1/0 insulated aluminum conductors having a length of 91 cm (36 in). The cable insulation thickness shall be selected according to its voltage class (see Table 10 of IEEE 386).Equalizers used shall be in accordance with ANSI C119.4.The bushing bus shall be a flat, rectangular, bus bar 356 mm (14 in) long, 102 mm (4 in) wide, and 10 mm (3/8 in) thick. The bushing wells shall be mounted 31 cm (12 in) apart centered along the midline of the bus bar. The bushing well studs shall be tightened to the bus bar using an installation torque of 9 N·m  $\pm$  1 N·m (80 lbf·in  $\pm$  10 lbf·in).

Unless otherwise specified by the manufacturers, the elbow male contact probe shall be threaded into the elbow compression lug using an installation torque of  $9 \text{ N}\cdot\text{m} \pm 1 \text{ N}\cdot\text{m}$  ( $80 \text{ lbf}\cdot\text{in} \pm 10 \text{ lbf}\cdot\text{in}$ ).

Current-cycling tests shall be conducted at an ambient temperature of  $15 \text{ }^\circ\text{C}$  to  $35 \text{ }^\circ\text{C}$  in a space free of drafts.

The current-cycle amperes shall be adjusted during the current-on period of the first five cycles to result in a steady-state temperature rise of  $100 \text{ }^\circ\text{C}$  to  $105 \text{ }^\circ\text{C}$  on the control conductor. This current shall then be used during the remainder of the test current-on periods, regardless of the temperature of the control conductor.

The test shall consist of 50 current cycles, with the current on 4 h and off 2 h for each cycle. At the end of each current-on cycle, the assembly shall be de-energized and within 3 min be submerged in water at  $5 \text{ }^\circ\text{C} \pm 5 \text{ }^\circ\text{C}$  for the remainder of the current-off cycle. At the end of the 10th, 25th and 40th cycles ( $\pm 2$  cycles), after the samples have returned to room temperature, a short time ac current of  $3500 \text{ A} \pm 300 \text{ A rms}$  shall be applied to each sample for a minimum of 3 s.

The temperature of at least the following current transfer points shall be measured at the end of each cycle with the current on:

- a) Probe to compression lug
- b) Probe to female contact
- c) Female contact structure to metallic housing (piston contact)
- d) Between bushing insert and bushing well.

These temperatures shall not exceed the temperature of the control conductor.

The temperature differences between the control conductor and the connector shall show a condition of stability from the fifth cycle to the end of the test. Stability is indicated when the change in the individual differences is not more than  $10 \text{ }^\circ\text{C}$  from the average of the measured differences in this interval for this connector.

The dc resistance of the connector system shall be measured at the end of cycles 10, 20, 30, 40, and 50 ( $\pm 2$  cycles). The dc resistance measurements shall be made between the elbow cable equalizer and the bushing stud after the connector system has stabilized at ambient temperature. Ambient temperature shall be measured by devices located within 61 cm (2 ft.) of the test loop but in a location that minimizes the effect of thermal convection. The ambient temperature shall be recorded at the same time as each set of resistance measurements, and the resistance shall be corrected to  $20 \text{ }^\circ\text{C}$ . The dc resistance shall be stable over the period of measurement. Stability is achieved when any resistance measurement, including allowance for instrument accuracy, does not vary more than  $\pm 5\%$  from the average of all the measurements in this interval.

## Results

Temperature Sensor Area : a-compression lug/ probe b-probe/louver contact

Unit °C

Cycle#	A15		A16		A17		A18		cable	Room Temp	Water Temp
	a.	b.	a.	b.	a.	b.	a.	b.			
6	59.2	48.5	58.9	49.1	58.4	49.3	53.1	48.9	101.2	25.1	7.0
7	57.3	46.3	56.1	47.2	58.7	49.2	52.3	47.9	101.5	23.9	7.3
8	58.2	46.8	57.2	46.9	59.5	48.7	54.6	48.7	101.1	22.1	7.9
9	58.6	47.2	57.5	47.1	59.9	47.6	53.2	48.1	100.7	27.3	8.2
10	57.9	46.2	56.4	46.7	59.3	47.9	53.2	47.6	101.3	25.9	7.8
11	59.1	48.1	58.3	47.1	59.1	47.1	52.9	47.8	101.0	23.5	7.3
12	58.8	47.8	57.4	45.8	58.3	47.2	54.6	47.7	100.8	24.8	7.5
13	57.4	46.1	56.1	49.9	58.5	46.9	53.6	48.5	101.9	27.3	7.9
14	57.7	46.5	56.3	47.4	57.4	46.6	53.9	47.3	101.4	23.1	8.0
15	58.6	47.7	57.2	48.1	59.3	46.9	54.4	47.9	102.1	21.9	7.7
16	57.3	46.4	55.9	45.8	57.1	45.8	52.5	48.3	101.6	25.1	7.4
17	59.4	49.0	57.8	47.6	59.2	47.2	54.3	48.1	101.2	29.4	7.1
18	60.1	49.2	57.2	46.9	58.9	46.1	55.9	47.7	100.9	26.9	7.3
19	58.5	48.5	58.1	46.5	58.5	46.8	56.2	47.5	101.1	24.1	7.5
20	58.1	48.6	59.0	49.1	58.7	48.7	57.8	49.7	100.7	32.2	7.6
21	58.9	49.1	57.5	45.1	57.5	48.5	54.6	48.6	102.5	28.5	7.8
22	59.3	48.8	57.9	44.7	57.3	48.8	53.3	47.3	101.7	25.3	8.2
23	57.5	47.2	56.2	43.9	58.6	49.1	54.5	47.6	102.2	24.4	7.9
24	60.2	50.2	58.1	45.9	59.4	49.7	54.2	48.2	101.8	29.4	7.6
25	61.5	51.1	56.9	44.7	58.8	48.9	52.8	47.2	101.6	27.2	7.2
26	60.7	49.8	57.0	45.3	59.8	47.7	51.2	47.4	102.3	24.5	7.4
27	59.2	49.4	58.3	46.6	58.3	48.1	53.8	46.9	102.0	27.5	7.8
28	58.6	48.7	57.6	46.2	59.6	49.2	54.8	47.7	101.9	30.3	8.1
29	58.2	48.5	59.2	46.9	57.5	48.2	54.7	47.4	102.1	26.5	7.6
30	57.9	48.1	56.4	46.3	57.8	49.4	53.4	47.3	102.2	23.4	7.9
31	58.4	48.6	58.1	47.2	58.1	49.2	54.9	46.9	101.8	24.1	7.5
32	59.3	49.0	58.4	47.3	59.2	49.9	53.5	46.4	102.1	29.7	7.3
33	58.1	48.6	57.9	46.8	57.9	48.5	52.4	44.9	102.3	27.1	7.7
34	54.3	44.4	58.3	47.0	57.1	44.2	49.3	43.4	101.3	23.1	7.8
35	59.2	46.8	58.2	47.6	57.8	46.5	49.2	44.6	101.8	24.3	8.1
36	57.6	44.6	57.6	46.1	57.9	43.6	48.7	41.7	100.2	27.2	7.8

37	58.3	44.8	57.4	45.9	59.2	44.6	48.2	41.4	101.1	28.0	7.4
38	58.4	45.5	58.2	46.0	59.9	44.8	48.9	42.1	101.0	29.5	7.2
39	58.6	46.7	58.5	48.4	59.6	45.2	48.1	45.1	101.9	27.0	7.5
40	58.2	45.0	56.4	45.0	58.5	44.1	48.5	43.0	101.7	29.0	8.2
41	55.0	43.8	52.9	42.7	58.5	43.2	46.9	45.5	101.9	29.1	7.7
42	56.9	44.9	54.7	44.6	58.3	44.9	47.4	44.4	101.5	30.1	7.4
43	54.6	43.0	51.7	42.1	57.8	43.9	46.1	43.8	101.6	31.2	7.9
44	64.4	49.3	57.2	47.4	58.5	51.4	52.5	48.6	100.1	27.7	8.1
45	63.9	51.9	59.3	49.1	60.4	48.2	53.6	46.4	101.2	26.9	7.7
46	62.5	50.6	58.1	49.6	61.6	47.3	53.1	46.2	102.0	26.5	7.5
47	64.1	52.2	58.7	50.1	59.7	50.4	52.2	46.7	100.5	27.5	7.2
48	61.5	51.8	59.5	49.9	58.8	50.1	54.6	47.6	101.9	27.1	7.6
49	62.4	50.5	58.3	50.8	57.5	50.9	53.2	46.9	102.5	26.9	8.0
50	63.8	52.4	58.1	50.6	56.9	51.8	52.8	48.5	101.3	26.4	7.9
平均	59.1	47.9	57.3	46.9	58.7	47.6	52.5	46.7	101.6	26.6	7.5
Max Temp Delta (Cycle)	5.3 (44)	4.9 (43)	5.6 (43)	4.8 (43)	3.0 (46)	4.4 (41)	6.4 (43)	5.3 (37)	100.1 ~ 102.5	21.9 ~ 32.2	7.0 ~ 8.2
Remark	Temp difference does not vary more than 10 °C, meets the requirement of the standard.										

### Resistance Measurement

Unit : mΩ

Date	Week #	Room Temp	Equalizers-I1 / Bushing Well-I1		Equalizers-I2 / Bushing Well-I2		Equalizers-I3 / Bushing Well-I3		Equalizers-I4 / Bushing Well-I4	
			Value	%	Value	%	Value	%	Value	%
10/17	9	27.3	0.69	0.98%	0.70	1.00%	0.69	0.99%	0.69	0.98%
10/20	20	32.2	0.70	1.00%	0.71	1.01%	0.69	0.99%	0.70	0.99%
10/23	32	29.7	0.70	1.00%	0.70	1.00%	0.71	1.02%	0.71	1.01%
10/25	40	29.0	0.71	1.01%	0.70	1.00%	0.70	1.00%	0.70	0.99%
10/28	50	26.4	0.70	1.00%	0.69	0.98%	0.69	0.99%	0.71	1.01%
Average			0.70		0.70		0.696		0.702	

**Short-time Current 3500A/3 sec**

**25kV200A Elbow 2014-Oct-17 9<sup>th</sup> Cycle**

3.5kA/3sec X/R 6

Sample Number	1 <sup>st</sup> Cycle Current (peak)	1 <sup>st</sup> Cycle Current (rms)	Current (rms)	Time	Verification	Result
A15&A16	7.61kA	5.38kA	4.47kA	3.05 sec	Normal	PASS
A17&A18	8.2kA	5.8kA	4.17kA	3.05 sec	Normal	PASS

**25kV200A Elbow 2014-Oct-21 23<sup>rd</sup> Cycle**


3.5kA/3sec X/R 6

Sample Number	1 <sup>st</sup> Cycle Current (peak)	1 <sup>st</sup> Cycle Current (rms)	Current (rms)	Time	Verification	Result
A15&A16	6.86kA	4.85kA	4.21kA	3.09 sec	Normal	PASS
A17&A18	8.43kA	5.96kA	4.23kA	3.07 sec	Normal	PASS


**25kV200A Elbow 2014-Oct-25 40<sup>th</sup> Cycle**

3.5kA/3sec X/R 6

Sample Number	1 <sup>st</sup> Cycle Current (peak)	1 <sup>st</sup> Cycle Current (rms)	Current (rms)	Time	Verification	Result
A15&A16	7.32kA	5.17kA	4.1kA	3.07 sec	Normal	PASS
A17&A18	7.61kA	5.38kA	4.15kA	3.08 sec	Normal	PASS




A15&A16 3.5kA/3sec Short-time Current (2014-Oct-17 9<sup>th</sup> Cycle)




A17&A18 3.5kA/3sec Short-time Current (2014-Oct-17 9<sup>th</sup> Cycle)







A15&A16 3.5kA/3sec Short-time Current (2014-Oct-21 23<sup>rd</sup> Cycle)



A17&A18 3.5kA/3sec Short-time Current (2014-Oct-21 23<sup>rd</sup> Cycle)



A15&A16 3.5kA/3sec Short-time Current (2014-Oct-21 40<sup>th</sup> Cycle)



A17&A18 3.5kA/3sec Short-time Current (2014-Oct-21 40<sup>th</sup> Cycle)






Fig 13-1 Test Setup Diagram

## 14. Accelerated Sealing Life Test

### Object

To verify the connector can maintain a long-term seal at all interfaces to prevent the entrance of moisture.

### Testing Samples and Mating Parts

Elbow	CHARDON 25-DE200T	4 PCS
Bushing	CHARDON 24-DIB250	4 PCS

### Mating Parts


Cable Conductor Type	1/0 AWG(Aluminum)
Cable Insulation Thickness	220 mil
Conductor	200A Bi-Metal Lug
Equalizers	Aluminum Equalizers Size : 106mm(L)20mm(OD)10.1mm(ID)
Bushing Bus	356mm(L), 102mm(W),10mm(T)

### Procedure


1. The four connector assemblies shall be placed in an oven having 121 °C temperature and remain there for three weeks.
2. After the time has elapsed, the four samples shall be subjected to 50 cycles of the following sequence of operations: The assemblies shall be heated in air using sufficient current to raise the temperature of the connector of the control cable to 90 °C ± 5 °C for 1 hour.
3. The assemblies shall be de-energized and within 3 min, submerged in 25 °C ± 10 °C conductive water (5000 Ω-cm maximum) to a depth of 30 cm (1 ft) for 1 hour.
4. After 50<sup>th</sup> cycle, the connector and cable assembly shall withstand a design impulse test of IEEE 7.5.3(1.2\*50μS impulse wave of 125kV, 3 positive and 3 negative) and test point voltage test.( During the impulse test, the bushing well and bushing bus were soaked into the silicone oil.)

## Results


Sample #	PD Testing Before Acc Life Sealing Test	AC Withstand Testing Before Acc Life Sealing Test	Impulse Testing Before Acc Life Sealing Test	PD Testing After Acc Life Sealing Test	Test Point Voltage Testing
B1	23kV0.5pC	40kV/1m Pass	±125kV 3 Shots Each, Pass	±125kV 3 Shots Each, Pass	13.0kV
B2	23kV0.6pC	40kV/1m Pass			13.0kV
B3	23kV0.6pC	40kV/1m Pass			12.5kV
B4	23kV0.8pC	40kV/1m Pass			13.0kV
Remark	<ul style="list-style-type: none"> <li>● Tested with Bushing Insert and Elbow Assembly</li> <li>● Cable Temp : 89.1~91.3°C</li> <li>● Water Temp : 29.8~32.9°C</li> <li>● Resistance of Water : 3461 Ω-cm</li> <li>● Depth of Water : 30 cm</li> <li>● Test Point Voltage Testing is applied with 15.0kV</li> </ul>				




Impulse Testing Waveform before Accelerated Sealing Life Test – Positive Wave



Impulse Testing Waveform before Accelerated Sealing Life Test – Negative Wave



Impulse Testing Waveform after Accelerated Sealing Life Test – Positive Wave



Impulse Testing Waveform after Accelerated Sealing Life Test – Negative Wave




Fig 14-1 Test Setup Diagram



## 15. Current-cycling test – Thermal Test with Off-axis Operation

### Object

The purpose of this test is to demonstrate that loadbreak and deadbreak 200 A connectors can carry rated load current after being subjected to an off-axis operating force. Successful completion of these tests shall be considered as evidence that the connector meets its rating.

### Testing Samples

Deadbreak Elbow	25-DE200TC	4 PCS
-----------------	------------	-------

### Mating Parts

Bushing Well	Chardon 200A Bushing Well CH200BW	4 PCS
Cable Conductor Type	1/0 AWG Aluminum Cable	
Cable Insulation Thickness	260 mil	
Conductor	Chardon 200A BiMetal Connector 1/0	
Equalizers	Aluminum Equalizers Size : 106mm(L), 20mm(OD), 10.1mm(ID)	
Bushing Bus	356mm(L),102mm(W),10mm(T)	

### Procedure

The purpose of this test is to demonstrate that loadbreak and deadbreak 200 A connectors can carry rated load current after being subjected to an off-axis operating force. Successful completion of these tests shall be considered as evidence that the connector meets its rating.

Each connector shall be subjected to six cycles, each consisting of a mechanical operation as specified in 7.10.2.1 and current cycling as specified in 7.10.2.2. of IEEE 386

The elbow shall be disassembled with a 12.7 mm (0.5 in) wide pulling band, as shown in Figure 21 of IEEE 386 for application of an off-axis force. Grounding tabs or other obstructions may be removed to apply the pulling band. No provision is made for an off-axis closing force since it is not consistently reproducible.

Four connectors shall be assembled in series on AWG No. 1/0 insulated aluminum

conductors having a length of 91 cm (36 in). The cable insulation thickness shall be selected according to its voltage class (see Table 10 of IEEE 386).

## Results

Thermal couple installation areas:

- 1) At the compression lug
- 2) At the midpoint of the bushing contact

Unit: °C

Cycle#	A11		A12		A13		A14		Control Cable	Room Temp
	A11-1	A11-2	A12-1	A12-2	A13-1	A13-2	A14-1	A14-2		
1	71.8	60,3	63.2	48.5	68.2	52.3	73.3	61.8	89.1	30.0
2	72.3	60.0	63.4	49.9	67.7	51.9	72.4	57.5	90.4	29.6
3	72.5	60.1	65.5	50.4	66.4	51.7	74.2	57.9	90.6	29.0
4	72.4	60.5	66.4	53.1	68.1	53.2	68,6	57.1	90.5	30.6
5	72.4	61.0	66.3	53.0	66.6	53.9	70.5	57.4	90.5	30.0
6	72.6	61.7	66.5	52.7	68.2	53.7	70.7	57.6	90.8	29.4
7	73.1	62.5	66.1	53.5	67.8	53.2	70.8	57.3	90.9	29.0
8	73.3	62.4	65.4	51.7	68.3	53.6	72.3	58.1	90.9	28.8
9	72.7	60.5	61.0	50.2	66.8	50.6	68.7	54.2	90.8	28.1
10	73.3	61.0	61.2	49.7	66.5	50.8	68.1	54.8	91.0	27.5
11	73.1	62.2	62.4	49.3	66.3	50.9	68.5	54.0	91.0	27.4
12	73.6	63.2	63.0	49.5	67.0	52.3	67.7	53.6	91.2	29.2
13	73.5	63.2	63.3	49.1	67.7	52.0	68.0	53.2	91.3	28.4
14	73.2	63.1	63.6	49.2	66.8	51.5	67.3	53.5	91.2	27.8
15	72.9	63.0	64.2	49.6	67.7	51.7	67.0	53.0	90.8	27.0
16	73.6	63.5	65.0	49.9	68.3	52.3	68.7	53.1	90.9	28.0
17	73.7	63.4	64.8	48.9	67.6	51.7	67.7	52.6	91.1	26.7
18	73.4	63.2	64.5	49.1	67.3	51.1	67.1	52.4	90.8	26.6
19	73.9	63.4	65.2	49.9	67.1	51.0	68,0	52.6	90.6	26.3
20	74.2	62.4	63.4	49.2	72.2	53.8	69.5	55.3	91.4	28.6
21	74.3	61.7	62.9	49.6	72.0	55.4	70.2	57.4	89.8	27.8
22	74.2	62.0	63.3	49.9	72.1	57.1	71.3	57.8	89.3	27.1
23	74.5	63.1	64.5	50.2	71.5	57.1	73.2	58.0	88.9	26.6
24	73.4	63.2	65.0	51.2	72.3	59.2	72.7	59.1	89.1	29.1
25	73.1	62.7	65.1	50.5	74.0	58.4	74.7	60.2	89.1	27.5
26	73.9	62.9	65.2	51.4	74.2	58.2	74.8	60.3	89.1	26,3

27	73.7	62.5	65.3	51.2	74.6	58.8	75.2	60.5	89.1	26.0
28	73.8	62.3	64.8	49.4	72.2	57.7	76.5	61.3	89.1	28.6
29	72.6	62.1	63.9	50.6	73.1	58.0	76.2	61.0	89.0	28.2
30	73.1	62.7	65.1	51.5	74.1	58.2	76.1	60.7	89.1	27.6
31	73.0	62.4	64.8	52.0	75.2	59.3	75.4	60.2	88.8	26.1
32	73.2	62.5	63.7	51.3	76.3	60.1	75.3	58.6	89.1	29.2
33	74.0	62.8	63.5	51.6	77.7	60.5	76.0	57.3	89.3	28.0
34	73.7	63.2	63.2	51.3	76.8	60.2	75.2	57.8	89.5	26.6
35	73.6	62.8	63.0	51.0	76.3	60.6	76.0	56.2	89.5	26.0
36	73.4	62.8	62.7	50.7	76.0	59.2	76.2	57.4	90.4	29.2
37	73.1	62.2	62.5	50.6	75.7	59.4	76.1	57.2	89.7	27.8
38	73.9	62.4	62.6	50.3	75.3	59.4	75.3	56.7	89.0	26.7
39	73.4	62.0	62.2	50.4	76.2	59.6	75.1	56.2	89.0	26.0
40	72.6	62.8	62.7	51.3	75.7	59.2	74.3	56.0	89.1	29.0
41	72.5	63.0	62.8	51.5	75.1	59.0	74.5	55.6	89.1	28.2
42	73.0	63.6	63.2	51.5	76.1	59.5	74.1	56.7	89.0	28.1
43	73.1	63.9	63.5	51.6	77.1	60.2	75.0	56.6	89.1	26.8
44	72.6	64.0	63.6	52.0	76.6	60.4	74.6	57.3	89.2	26.2
45	73.5	63.8	64.1	52.5	76.2	59.6	75.9	57.9	88.9	29.5
46	74.4	64.0	64.7	52.6	76.0	59.2	75.1	56.8	89.1	28.1
47	74.6	64.2	64.7	52.7	77.1	60.3	75.3	57.7	89.2	28.3
48	75.1	64.8	65.3	53.4	77.3	60.0	75.1	60.3	89.5	30.2
Ave.	73.4	61.3	64.0	50.8	72.0	56.2	69.7	57.0	89.9	27.4
Remark	After six cycles, the average temperatures of each thermal couple are not higher than control cable temperature.									






Fig 15-1 Current Cycling Test Setup

## APPENDIX -External Test Report



Powertech Labs Inc. • 12388 - 88th Avenue, Surrey, B.C. Canada • V3W 7R7


### Test Report № PL-26015B


The tests were performed in accordance with  
IEEE Standard 592-2007, section 4.3

<b>Project №:</b>	PL-26015	<b>Test Date:</b>	13 September 2013
<b>Tested equipment:</b>	Two Separable Insulated Connectors manufactured by Chardon Taiwan Corporation, prefaulted in accordance with IEEE Standard 592-2007, Figure 1. The samples were numbered by the client.		
<b>Voltage rating:</b>	15.2 kV <sub>phase-to-ground</sub>		
<b>Test voltage:</b>	11.7 kV <sub>phase-to-ground</sub>		
<b>Test current:</b>	10 kA <sub>rms</sub>		
<b>Markings:</b>	Elbow- Chardon, 15.2/26.3 kV, 200A Load Break Cable- TPC. 25 kV 1/C #1AWG CU, XLPE 260 mils		
<b>Tests performed:</b>	Fault-Current Initiation Tests per Section 4.3. Each sample was subjected to two current pulses at 10 kA <sub>rms</sub> , 10 cycles.		
<b>Test results:</b>	All tested samples passed the tests.		
<b>Remarks:</b>	Identification of the tested Connectors was based on the markings on the samples. The samples were supplied already prefaulted.		

Tested by:

Reviewed by:

  
K. Tabarrat M.A.Sc., EIT  
Electrical Engineer, High Power Lab

  
21 October 2013  
T. Stefanski M.Sc., P. Eng.  
Head of High Power Lab

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*