

# TEST REPORT

2014TC00609

1/245

CLASSIFICATION Type Test

TEST OBJECT Automatic circuit polymer recloser

DESIGNATION CKMR

3 phases 15.5 kV 800 A 16 kA 50 Hz

RECEIPT No. TRD14C00436 (May 13, 2014 )

APPLICANT Chardon Korea Co., LTD.  
191-28, Gajang-Ro, Jeongnam-Myeon, Hwaseong-Si, Gyeonggi-Do, Korea

MANUFACTURER Chardon Korea Co., LTD.  
191-28, Gajang-Ro, Jeongnam-Myeon, Hwaseong-Si, Gyeonggi-Do, Korea

DATE OF TESTS July 08, 2014 ~ September 05, 2014

DATE OF ISSUE September 25, 2014

The test object, constructed in accordance with the description, essential drawings and photographs incorporated in this Type Test Report has been subjected to the series of proving tests in accordance with

IEC 62271-111 Edition 2.0:2012-09

This Type Test Report has been issued by KERI.

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performances are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page No.3 ~ No.4.

The Type Test Report applies only to the test object. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Report are permitted without written permission from KERI. Electronic copies in PDF-format or scanned version of this Report may be available and have the status "for information only". The sealed version of the Report is only the valid version.

TOTAL No. OF PAGES(245) : records (46), photographs (13), circuit diagrams (8),  
drawings & descriptions (4), attachments(3), oscillograms (171)



Prepared by

Kim, Seok-Sou

Verified by  
(Technical manager)

Kim, Kyong-Woon

Approved by

Rhyou, Hyeong-Kee

High Power High Voltage Testing &amp; Evaluation Division

**KERI**

KOREA ELECTROTECHNOLOGY RESEARCH INSTITUTE  
12, bulmosan-ro 10beon-gil, Seongsan-gu, Changwon-si, Gyeongsangnam-do, 642-120, Korea  
Tel : +(0)82-(0)55-280-1510, Fax : +(0)82-(0)55-280-1512, www.keri.re.kr