



中国认可  
国际互认  
检测  
TESTING  
CNAS L069



# TEST REPORT

CEPRI-EETC08-2020-0728 (E)

Client: SHANGHAI CHARDON ELECTRIC LTD.

Object: 26/35 (40.5) kV cold shrinkable outdoor  
termination

Type: 35-CSTO/TFK 1×185

Test Category: Type Tests



POWER INDUSTRY QUALITY INSPECTION AND TEST  
CENTER FOR ELECTRIC EQUIPMENT

## Catalogue

1. Catalogue.....	1
2. Signature Page.....	2
3. Test Results.....	3
4. Content.....	6
5. Appendix A Object Parameters.....	9
6. Appendix B The Main Test Devices.....	10
7. Appendix C Waveforms.....	11
8. Appendix D Other Information.....	15

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC08-2020-0728(E) Total 22 Page 2
Client	SHANGHAI CHARDON ELECTRIC LTD.	Manufacturer	SHANGHAI CHARDON ELECTRIC LTD.
Object	26/35 (40.5) kV cold shrinkable outdoor termination	Type	35-CSTO/TFK 1×185
Sampling procedure	by the Client	Serial No.	EETC08-20/08/12-003
Test Category	Type Tests	Date	2020.08.14~2021.01.12



Requirements	<p>1. GB/T 12706.4—2008 Power cables with extruded insulation and their accessories for rated voltages from 1 kV (<math>U_m=1.2</math> kV) up to 35 kV (<math>U_m=40.5</math> kV) — Part 4: Test requirements on accessories for cables with rated voltages from 6 kV (<math>U_m=7.2</math> kV) up to 35 kV (<math>U_m=40.5</math> kV)</p> <p>2. IEC 60502-4:2010 Power cables with extruded insulation and their accessories for rated voltages from 1 kV (<math>U_m=1.2</math> kV) up to 30 kV (<math>U_m=36</math> kV) - Part 4: Test requirements on accessories for cables with rated voltages from 6 kV (<math>U_m=7.2</math> kV) up to 30 kV (<math>U_m=36</math> kV)</p>		
Conclusion	<p>According to GB/T 12706.4—2008 and IEC 60502-4:2010, type tests were performed on 26/35 (40.5) kV cold shrinkable outdoor terminations which were provided by SHANGHAI CHARDON ELECTRIC LTD. All the results were in accordance with the requirements.</p>		
Note	/		



Tested by:	邓凯 邓凯	周诚 周诚
Checked by:	彭超 彭超	Verified by: 苗付贵 苗付贵
Approved by:	阎孟昆 阎孟昆	Date of issue: 2021-01-28

Test Results

No.	Item	Requirements	Results	Evaluation				
1	Sequence 1.1	/	/	/				
1.1	AC voltage test	Neither breakdown nor flashover shall occur at 117 kV for 5 min	No breakdown and flashover occurred on the combination samples at 117 kV for 5 min	passed				
1.2	DC voltage test	Neither breakdown nor flashover shall occur at 104 kV for 15 min	No breakdown and flashover occurred on the combination samples at 104 kV for 15 min	passed				
1.3	AC voltage test under rain	Neither breakdown nor flashover shall occur at 104 kV for 1 min	No breakdown and flashover occurred on the combination samples at 104 kV for 1 min	passed				
1.4	Partial discharge test at ambient temperature	The magnitude of the discharge at 45 kV shall not exceed 10 pC	Phase	1	2	3	4	passed
			Voltage (kV)	45	45	45	45	
			Noise background (pC)	2.3	2.3	1.7	1.7	
			Discharge (pC)	2.3	2.3	1.7	1.7	
1.5	Impulse voltage test at 95 °C~100 °C	Neither breakdown nor flashover shall occur at 10 positive and 10 negative impulses of 200 kV	No breakdown and flashover occurred on the combination samples at 10 positive and 10 negative impulses of 200 kV (See Appendix C.1)	passed				
1.6	Heating cycle voltage test in air	Neither breakdown nor flashover shall occur during 60 cycles in air at the conductor temperature of 95°C to 100°C and 65 kV	No breakdown and flashover occurred on the combination samples during 60 cycles in air at the conductor temperature of 95°C to 100°C and 65 kV	passed				
1.7	Immersion test	10 cycles in water at the conductor temperature of 95 °C to 100 °C,each cycle lasts for 8h, whereas 5h for heating, 3h for cooling	The Immersion test was finished according to standards	/				
1.8	Partial discharge test at 95°C~100°C	The magnitude of the discharge at 45 kV shall not exceed 10 pC	Phase	1	2	3	4	passed
			Voltage (kV)	45	45	45	45	
			Noise background (pC)	2.0	2.0	1.6	1.6	
			Discharge (pC)	2.0	2.0	1.6	1.6	

No.	Item	Requirements	Results				Evaluation	
			Phase	1	2	3		4
1.9	Partial discharge test at ambient temperature	The magnitude of the discharge at 45 kV shall not exceed 10 pC	Voltage (kV)	45	45	45	45	passed
			Noise background (pC)	1.9	1.9	2.4	2.4	
			Discharge (pC)	1.9	1.9	2.4	2.4	
1.10	Impulse voltage test	Neither breakdown nor flashover shall occur at 10 positive and 10 negative impulses of 200 kV	No breakdown and flashover occurred on the combination samples at 10 positive and 10 negative impulses of 200 kV (See Appendix C.2)				passed	
1.11	AC voltage test	Neither breakdown nor flashover shall occur at 65 kV for 15 min	No breakdown and flashover occurred on the combination samples at 65 kV for 15 min				passed	
1.12	Examination	It is advised that the accessory is examined for signs of any of the following: ( i ) cracking in the filling media and/or tape or tube components; ( ii ) a moisture path across a primary seal; ( iii ) corrosion and/or tracking and/or erosion; ( iv ) leakage of an insulating material.	( i ) No cracking in the filling media and tape or tube components; ( ii ) No moisture path across a primary seal; ( iii ) No evident corrosion, tracking and erosion; ( iv ) No leakage of an insulating material.				passed	
2	Sequence 1.2 and 1.3	/	/				/	
2.1	AC voltage test	Neither breakdown nor flashover shall occur at 117 kV for 5 min	No breakdown and flashover occurred on the combination samples at 117 kV for 5 min				passed	
2.2	DC voltage test	Neither breakdown nor flashover shall occur at 104 kV for 15 min	No breakdown and flashover occurred on the combination samples at 104 kV for 15 min				passed	
2.3	Thermal short-circuit test (screen)	No visible deterioration at 3.5 kA, 1 s, twice	No visible deterioration at 3.502 kA, 1.01 s and 3.569 kA, 1.02 s (See Appendix C.4)				passed	

Test Report		Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC08-2020-0728(E) Total 22 Page 5
No.	Item	Requirements	Results	Evaluation
2.4	Thermal short-circuit test (conductor)	No visible deterioration at 24.5kA, 2 s, twice	No visible deterioration at 24.97 kA, 2.03s and 24.81 kA, 2.03s (See Appendix C.5)	passed
2.5	Dynamic short-circuit test	No visible deterioration at 86.5 kA, not less than 10 ms	No visible deterioration at 86.92 kA, 86 ms (See Appendix C.6)	passed
2.6	Impulse voltage test	Neither breakdown nor flashover shall occur at 10 positive and 10 negative impulses of 200 kV	No breakdown and flashover occurred on the combination samples at 10 positive and 10 negative impulses of 200 kV (See Appendix C.3)	passed
2.7	AC voltage test	Neither breakdown nor flashover shall occur at 65 kV for 15 min	No breakdown and flashover occurred on the combination samples at 65kV for 15 min	passed
2.8	Examination	It is advised that the accessory is examined for signs of any of the following: ( i ) cracking in the filling media and/or tape or tube components; ( ii ) a moisture path across a primary seal; (iii) corrosion and/or tracking and/or erosion; (iv) leakage of an insulating material.	( i ) No cracking in the filling media and tape or tube components; ( ii ) No moisture path across a primary seal; (iii) No evident corrosion, tracking and erosion; (iv) No leakage of an insulating material.	passed
3	Sequence 1.5	/	/	/
3.1	Salt fog tests	Neither breakdown nor flashover, no more than three trippings, no substantial damage shall occur at 32.5 kV for 1000 h	No breakdown, flashover, tripping, substantial damage occurred on the combination samples at 32.5 kV for 1000 h	passed

No.	Item	Requirements	Results	Evaluation
3.2	Examination	<p>It is advised that the accessory is examined for signs of any of the following:</p> <ul style="list-style-type: none"> <li>( i ) cracking in the filling media and/or tape or tube components;</li> <li>( ii ) a moisture path across a primary seal;</li> <li>( iii ) corrosion and/or tracking and/or erosion;</li> <li>( iv ) leakage of an insulating material.</li> </ul>	<ul style="list-style-type: none"> <li>( i ) No cracking in the filling media and tape or tube components;</li> <li>( ii ) No moisture path across a primary seal;</li> <li>( iii ) No evident corrosion, tracking and erosion;</li> <li>( iv ) No leakage of an insulating material.</li> </ul>	passed

## Content

### 1. Sequence 1.1 in Table 4 of GB/T 12706.4—2008

#### 1.1 AC voltage test

##### 1.1.1 Test method

The test shall be carried out in accordance with GB/T 18889—2002, clause 4 and IEC 61442:2005, clause 4. Neither breakdown nor flashover shall occur at 117 kV for 5 min.

#### 1.2 DC voltage test

##### 1.2.1 Test method

The test was carried out in accordance with GB/T 18889—2002, clause 5 and IEC 61442:2005, clause 5. Neither breakdown nor flashover shall occur at 104 kV for 15 min.

#### 1.3 AC voltage test under rain

##### 1.3.1 Test method

The test shall be carried out in accordance with GB/T 18889—2002, clause 4 and IEC 61442:2005, clause 4. Neither breakdown nor flashover shall occur at 104 kV for 1 min.

#### 1.4 Partial discharge test at ambient temperature

##### 1.4.1 Test method

The test voltage shall be raised gradually to and held at 54 kV for 10 s and then slowly reduced to 45 kV. The test shall be carried out in accordance with GB/T 18889—2002, clause 7 and IEC 61442:2005, clause 7.

#### 1.5 Impulse voltage test at 95 °C~100 °C

##### 1.5.1 Test method

The test shall be carried out in accordance with GB/T 18889—2002, clause 6 and IEC 61442:2005, clause 6. The conductor of the cable shall be heated and stabilized for at least 2 h at a temperature of 95 °C~100 °C. Neither breakdown nor flashover shall occur at 10 positive and 10 negative impulses of 200 kV.

#### 1.6 Heating cycle voltage test in air

##### 1.6.1 Test method

The test shall be carried out in accordance with GB/T 18889—2002, clause 9 and IEC 61442:2005, clause 9. Each heating cycle in air shall be of at least 8 h duration with at least 2 h at a steady temperature of 5 °C

to 10 °C above the maximum cable conductor temperature in normal operation, followed by at least 3 h of natural cooling to within 10 °C of ambient temperature. Neither breakdown nor flashover shall occur during 60 cycles in air at the conductor temperature of 95°C to 100°C and 65 kV.

### 1.7 Immersion test

#### 1.7.1 Test method

The two terminations shall be immersed in water at ambient temperature for a depth not less than  $0.03^{+0.02}$ m. The test loop shall be erected upside down in water box. The terminations shall be totally immersed in water including the end of the sealing part. The test shall be carried out in accordance with IEC 61442:2005, clause 9. Each heating cycle in air shall be of at least 8 h duration with at least 2 h at a steady temperature of 5 °C to 10 °C above the maximum cable conductor temperature in normal operation, followed by at least 3 h of natural cooling to within 10 °C of ambient temperature. Neither breakdown nor flashover shall occur during 10 cycles in air at the conductor temperature of 95°C to 100°C. No voltage shall be applied to the test loop.

### 1.8 Partial discharge test at 95 °C~100 °C

#### 1.8.1 Test method

The test voltage shall be raised gradually to and held at 54 kV for 10 s and then slowly reduced to 45 kV. The test shall be carried out in accordance with GB/T 18889—2002, clause 7 and IEC 61442:2005, clause 7. The conductor temperature shall be of 95°C to 100°C during the test.

### 1.9 Partial discharge test at ambient temperature

#### 1.9.1 Test method

The test voltage shall be raised gradually to and held at 54 kV for 10 s and then slowly reduced to 45 kV. The test shall be carried out in accordance with GB/T 18889—2002, clause 7 and IEC 61442:2005, clause 7.

### 1.10 Impulse voltage test

#### 1.10.1 Test method

The test shall be carried out in accordance with GB/T 18889—2002, clause 6 and IEC 61442:2005, clause 6. Neither breakdown nor flashover shall occur at 10 positive and 10 negative impulses of 200 kV.

### 1.11 AC voltage test

#### 1.11.1 Test method

The test shall be carried out in accordance with GB/T 18889—2002, clause 4 and IEC 61442:2005, clause 4. Neither breakdown nor flashover shall occur at 65 kV for 15 min.

### 1.12 Examination

#### 1.12.1 Test method

It is advised that the accessory is examined for signs of any of the following: (i) cracking in the filling media and/or tape or tube components; (ii) a moisture path across a primary seal; (iii) corrosion and/or tracking and/or erosion; (iv) leakage of an insulating material.

## 2. Sequence 1.2 and 1.3 in Table 4 of GB/T 12706.4—2008

### 2.1 AC voltage test

#### 2.1.1 Test method

The test shall be carried out in accordance with GB/T 18889—2002, clause 4 and IEC 61442:2005, clause 4. Neither breakdown nor flashover shall occur at 117 kV for 5 min.



**2.2 DC voltage test****2.2.1 Test method**

The test was carried out in accordance with GB/T 18889—2002, clause 5 and IEC 61442:2005, clause 5. Neither breakdown nor flashover shall occur at 104 kV for 15 min.

**2.3 Thermal short-circuit test (screen)****2.3.1 Test method**

The test shall be carried out in accordance with GB/T 18889—2002, clause 10 and IEC 61442:2005, clause 10. At the beginning of the test, the cable conductor shall be heated to reach a steady temperature of 5 °C to 10 °C above the maximum cable conductor temperature in normal operation and shall last for at least 2 h. Then two short-circuits shall be applied to the screen. The short-circuit current and duration time shall be specified as the agreement between manufacturer and user according to the actual short-circuit condition of the power grid. Between the two short-circuits, the test loop shall be allowed to cool to a temperature less than 10 °C above its temperature prior to the first short-circuit. There shall be no visible deterioration on the samples.

**2.4 Thermal short-circuit test (conductor)****2.4.1 Test method**

The test shall be carried out in accordance with GB/T 18889—2002, clause 11 and IEC 61442:2005, clause 11. Two short-circuits shall be applied using AC to raise the conductor temperature to the maximum permissible short-circuit temperature (250°C) of the cable within 5 s. Between the two short-circuits, the test loop shall be allowed to cool to a temperature less than 10 °C above its temperature prior to the first short-circuit. There shall be no visible deterioration on the samples.

**2.5 Dynamic short-circuit test (conductor)****2.5.1 Test method**

The test shall be carried out in accordance with GB/T 18889—2002, clause 12 and IEC 61442:2005, clause 12. The dynamic short-circuit current value shall be 2.5 times of the thermal short-circuit value when the thermal short-circuit time equals 1s. There shall be no visible deterioration on the samples after the short-circuit lasts for at least 10ms.

**2.6 Impulse voltage test****2.6.1 Test method**

The test shall be carried out in accordance with GB/T 18889—2002, clause 6 and IEC 61442:2005, clause 6. Neither breakdown nor flashover shall occur at 10 positive and 10 negative impulses of 200 kV.

**2.7 AC voltage test****2.7.1 Test method**

The test shall be carried out in accordance with GB/T 18889—2002, clause 4 and IEC 61442:2005, clause 4. Neither breakdown nor flashover shall occur at 65 kV for 15 min.

**2.8 Examination****2.8.1 Test method**

It is advised that the accessory is examined for signs of any of the following: (i) cracking in the filling media and/or tape or tube components; (ii) a moisture path across a primary seal; (iii) corrosion and/or tracking and/or erosion; (iv) leakage of an insulating material.

**3. Sequence 1.5 in Table 4 of GB/T 12706.4—2008****3.1 Salt fog tests****3.1.1 Test method**

The test shall be carried out in accordance with GB/T 18889—2002, clause 13 and IEC 61442:2005, clause 13. Throughout the test duration, the mist spray shall be sprinkled at a rate of  $(0.4 \pm 0.1)L/h/m^3$  and its conductivity shall be  $(1\ 600 \pm 200)$  mS/m. Neither breakdown nor flashover, no more than three trippings, no substantial damage shall occur at 32.5 kV for 1000 h.

**3.2 Examination****3.2.1 Test method**

It is advised that the accessory is examined for signs of any of the following:( i ) cracking in the filling media and/or tape or tube components;( ii ) a moisture path across a primary seal;( iii ) corrosion and/or tracking and/or erosion;( iv ) leakage of an insulating material.

**Appendix A Object Parameters****A.1 Sample information**

The sample was received by Power Cable Station on 12/08/2020. The sample was in good condition with the factory number and the date of manufacture not provided.

**A.2 The number and installation of samples**


According to GB/T 12706.4—2008, it was required that eight sets of terminations to be tested were installed by the manufacturer on four length of cables forming No.1, NO.2, NO.3 and No.4 combination samples on which the type tests sequence 1.1, 1.2 and 1.3 were carried out. Four sets of straight joints were also installed by the manufacturer on the combination samples. The cable used in the combination samples was a XLPE insulated single-core cable for rated voltage 26/35 kV, a cross-section of 185sq.mm. In addition, another six sets of terminations to be tested were installed by the manufacturer on three length of cables forming combination samples on which the type tests sequence 1.5 were carried out.

**A.3 Photograph of samples**

The appearance of the sample

After salt fog test  
(the front view)After salt fog test  
(the rear view)

## A.4 Photograph of dissected samples



## Appendix B The Main Test Devices

No.	Name/ Type/ Specification	Serial No.	Measurement Range	Uncertainty / Accuracy class / Maximum Permissible Error	Calibration Institute	Valid Date
1	TRF300-0.002 AC voltage measurement system	110650	(0~300) kV	Grade 3	National high voltage measurement station	2022.07.14
2	JFD-2H PD measurement system	20041202	(0.5~1000) pC	Class 10	National high voltage measurement station	2021.05.19
3	FY I 900/600 Weakly damped capacitive voltage divider	11165-2-1	(0~900) kV	Class 3	National high voltage measurement station	2022.06.29
4	CY2009 Data collected system	SJCJ1100 8	20A~300 kA	Class 1	The 29th Metrology and Testing Center of the Ministry of Machinery Industry (Tianshui)	2021.02.27
5	LCC-V Heating cycle monitoring system	DLRXH0 3	(0~3000) A	Class 3	National high voltage measurement station	2024.10.26
6	287C Digital voltage meter	31470016	(0~700) V	Class 1	Vkan Certification & Testing Co., Ltd. Measuring Center	2021.05.10
7	DDS-307 conductivity meter	61050811 0058	(0~2000) mS/m	Class 3.0	Vkan Certification & Testing Co., Ltd. Measuring Center	2021.07.13

Appendix C Waveforms


C.1 The values and waveforms of impulse voltage on the combination samples before heating cycles voltage test

C.1.1 The values of impulse voltage test


Ambient temperature: 30.5°C      Relative humidity: 60%      Atmosphere: 0.1004MPa

Positive polarity (kV)	201	200	203	200	201	202	200	203	201	200
Negative polarity (kV)	202	202	200	200	200	200	199	201	201	201


C.1.2 The waveforms of impulse voltage test




The 1<sup>st</sup> positive impulses waveform



The 10<sup>th</sup> positive impulses waveform



The 1<sup>st</sup> negative impulses waveform



The 10<sup>th</sup> negative impulses waveform


C.2 The values and waveforms of impulse voltage on the combination samples after heating cycles voltage test

C.2.1 The values of impulse voltage test


Ambient temperature: 16.5°C      Relative humidity: 55%      Atmosphere: 0.1009MPa

Positive polarity (kV)	200	201	199	198	203	200	199	201	200	199
Negative polarity (kV)	199	198	198	201	201	201	201	198	199	199


C.2.2 The waveforms of impulse voltage test




The 1<sup>st</sup> positive impulses waveform



The 10<sup>th</sup> positive impulses waveform



The 1<sup>st</sup> negative impulses waveform



The 10<sup>th</sup> negative impulses waveform

**C.3 The values and waveforms of impulse voltage on the combination samples after thermal and dynamic short-circuit tests**

**C.3.1 The values of impulse voltage test**


Ambient temperature: 8.8°C

Relative humidity: 60%


Atmosphere: 0.1010MPa

Positive polarity (kV)	201	201	201	202	202	201	203	201	204	201
Negative polarity (kV)	202	202	202	201	202	202	202	201	203	202


**C.3.2 The waveforms of impulse voltage test**




The 1<sup>st</sup> positive impulses waveform



The 10<sup>th</sup> positive impulses waveform



The 1<sup>st</sup> negative impulses waveform



The 10<sup>th</sup> negative impulses waveform

C.4 The waveform of thermal short-circuit tests of the combination samples (screen)

No. 2020122401  
AA20

电力工业电气设备质量检验测试中心  
2020-12-24

09:28:54




No. 2020122501  
AA20

电力工业电气设备质量检验测试中心  
2020-12-25


08:48:01



C.5 The waveform of thermal short-circuit tests of the combination samples (conductor)




C.6 The waveform of dynamic short-circuit tests of the combination samples



## Appendix D Other Information

## D.1 Sample packing list


		35kV Cold Shrink Termination Kit Packing List		
No.	Product Name	QTY	Unit	Remark
1	Cold shrink termination	1	PC	
2	Cold Shrinkable Jacket Seal	1	PC	
3	Sealing tape	3	PCS	
4	Silicone lubricant	1	PC	
5	Paper towel	3	PCS	
6	PVC tape	1	PC	
7	Silicone tape	1	PC	
8	Sandpaper belt	2	PCS	
9	Gloves	1	Pair	
10	Installation Instructions	1	PC	
11	Packing List	1	PC	



## D.2 Identification of test cable (specified in GB/T 12706.3—2008)

rated voltage $U_0/U(U_m)$		26/35(40.5) kV
construction	core	single-core
	construction of screen	single-phase screen
conductor	material	copper
	type	round compact stranded
	cross section	185 mm <sup>2</sup>
	diameter	16.3 mm
insulation	material	XLPE
	thickness	10.5 mm
	diameter	39.5mm
screen	thickness of conductor screen	0.9 mm
	thickness of insulation screen	1.0 mm
	strippability of insulation screen	unstrippable
	diameter of insulation screen	41.6 mm
	metallic screen	copper tape
armour		/
oversheath	material	PVC
	diameter	49.3mm
mark of cable		YJV-26/35 3×185

D.3 Main structure dimensions of the samples



D.4 Installation Description



**35kV Cold Shrinkable Termination  
INSTALLATION**

**DESCRIPTION**

The Chardon Cold Shrinkable Termination offers easy installation and reliable performance when terminating indoor and outdoor medium voltage cables. Made from high quality, UV resistant, silicone rubber, the Chardon Cold Shrinkable termination offers a combination of durability and high performance in the field. The Chardon Cold Shrinkable Terminations include a stress controlling compound housing, preassembled on a plastic "hold out" tube. As the plastic hold out is removed, the stress-relief housing shrinks onto the cable. Chardon terminations are easy to install, and have a wide application range. No tools or heat sources are required. The products are designed to last the entire life of the cable. The Chardon Cold Shrinkable terminations are tested according to IEEE Standard 48 and IEC 60502.



**ORDERING INSTRUCTIONS:**

Standard Voltage Class	Part Number	Cable Insulation O.D. Range
35kV	35-CSTO -A	18.7 – 26.0
	35-CSTO -B	24.9 – 41.1
	35-CSTO -C	36.6 – 59.0

**COLD SHRINKABLE TERMINATION KIT CONTENT:**

- - Cold shrinkable termination (Contains hold out tubes)
- - Cold Shrinkable Jacket Seal
- - Paper towel
- - Silicone lubricant
- - Sealing tape
- - PVC tape
- - Sandpaper belt
- - Gloves
- - Installation & Operating instructions
- - Cable lug (Optional)
- - Grounding kit (Optional)

**CAUTION:** All associated apparatus must be de-energized during installation and/or maintenance.

**DANGER:** Do not touch or move energized product by hand. Failure to follow this instruction may result in serious or fatal injury, as well as damage to the product.

**SAFETY INFORMATION**

The instructions in this manual are not intended as a substitute for proper training or adequate experience in the safe operation of the equipment described. Only competent technicians, who are familiar with this equipment should install, operate and service it.

**The Chardon Cold Shrinkable Termination Part  
for Single Conductor Tape Shielded , Wire Shielded or Jacketed  
Concentric Neutral (JCN) Cable**



Tape Shielded Cable



Wire Shielded Cable




Jacketed Concentric Neutral (JCN) Cable

**INSTALL PROCEDURE**

**A. Prepare Cable**

**Tape Shielded Cable  
(Only this cable can use the  
grounding kit.)**



**STEP 1**

- Prepare cable using dimensions as shown in Fig.1.

**NOTE:** Ensure that all parts of the cable are not damaged. If there is any irreparable damage, a new cable needs to be made .If there is any impurity or slight damage on the surface of the insulation , it can be polished with fine sandpaper.

Part Number	35-A	35-B	35-C
Cable Insulation O.D. Range	18.7 – 26.0	24.9 – 41.1	36.6 – 59.0
A (mm)	510	520	525

**STEP 2**

- Sand off the sharp corners of the Cu conductive shield with coarse sandpaper and secure with copper tape.



**STEP 2**

- Sand off the sharp corners of the Cu conductive shield with coarse sandpaper and secure with copper tape.
- Use coarse sandpaper to grind the cable jacket about 25mm to rough the surface.
- Clean cable jacket and Cu conductive shield.
- Wrap 1 lap sealing tape onto the cable jacket about 15mm.
- Measure down 25mm from top of the cable jacket use constant-force spring to fix ground braid onto Cu conductive shield.



Fig.2

**STEP 3**

- Measure down 85mm from top of the Cu conductive shield wrap the sealing tape onto the ground braid.
- The height of the tape is 5mm (min) higher than that of the cable jacket.
- Wrap the PVC tape on top of it by 4 laps.
- Proceed to step B.




Fig.3

**Wire Shielded Cable / JNC Cable**

**STEP 1**

- Measure down from top of the cable as shown in Fig.4 . Remove cable jacket ( if jacketed cable is used) to expose neutral wires.
- Use copper wire to lash the neutral wires. Use coarse sandpaper to grind the cable jacket about 25mm to rough the surface.
- Clean cable jacket and Neutral wires.
- Wrap 1 lap sealing tape onto the cable jacket about 15mm.




Fig.4

Part Number	15-A	15-B	15-C
Cable Insulation	13.2-	16.8 -	25.3 -
O.D. Range	17.0	27.0	50.0
A (mm)	240	260	285

**STEP 2**

- Bend neutral wires down and parallel to cable.
- Use copper wire to secure neutral wires to cable jacket as shown in Fig.5.




Fig.5

**STEP 2**

- Bend neutral wires down and parallel to cable.
- Use copper wire to secure neutral wires to cable jacket as shown in Fig.6.




Fig.6

**STEP 3**

- Keep the 85mm semi-conductive shield and remove excess.
- Remove the insulation to expose the bare conductor for according to lug depth  $L+0.39''$ . Do not scratch the conductor.
- Wrap the sealing tape onto the neutral wires.
- Wrap the PVC tapes on top of it by 4 laps.




Fig.7

**NOTE:** Ensure that all parts of the cable are not damaged. If there is any irreparable damage, a new cable needs to be made. If there is any impurity or slight damage on the surface of the insulation, it can be polished with fine sandpaper.

**STEP 4**

- Mark semi-conductive shield for 45mm on the PVC tape.
- Place the Cold Shrinkable Jacket Seal onto the cable, aligning the mark with the end of the hold out tube. Take out hold out tube to complete the installation.
- Proceed to step B.




Fig.8

**B. Install Compression Connector**

**STEP 1**

- Clean the exposed conductor by using a wire brush.
- Place the compression connector on the exposed conductor and crimp it.




Fig.9

**STEP 2**

- Wrap the sealing tape to the insulation from connector pressure line.




Fig.10

**C. Install Termination**

**STEP 1**

- Polish and clean thoroughly the insulation by using sandpaper belt and paper towel then apply the silicone lubricant around the dotted line area.




Fig.11

**STEP 2**

- Mark semi-conductive shield for 70mm on the PVC tape
- Place the cold shrinkable termination onto the cable, aligning the mark with the end of the hold out tube. Take out hold out tube to complete the installation.




Fig.12

**STEP 3**

- Seal the top of the terminator at the connector area with Silicone tape



Fig.13

Inasmuch as CHARDON GROUP, Inc. has no control over the use which others may put the material, it does not guarantee that the same results as those described herein will be obtained. Each user of the material should make his own tests to determine the material's suitability for his own particular use. Statements concerning possible uses of the materials described herein are not to be construed as constituting a license under any CHARDON GROUP, inc. patent covering such use or as recommendations for use of such materials in the infringement of any patent.

FOR FURTHER INFORMATION WRITE TO



[sales@chardongroup.com](mailto:sales@chardongroup.com)