



中国认可  
国际互认  
检测  
TESTING  
CNAS L0699



# TEST REPORT

CEPRI-EETC02-2022-0041 (E)

Client: ANHUI CHARDON ELECTRIC LTD.

Object: Separated Connectors 17kV/45kV(17kV/50kV)

Coupling (Rear)T-Body Surge Arrester

Type: 17-RDTA45/17-FDTA45

(17-RDTA50/17-FDTA50)






Test Category: Type Test



POWER INDUSTRY QUALITY INSPECTION AND TEST  
CENTER FOR ELECTRIC EQUIPMENT

## Catalogue

1.Catalogue .....	1
2.Signature Page .....	2
3.Test Results .....	3
4.Content.....	4
5.Appendix A Object Parameters .....	16
6.Appendix B The Main Test Devices .....	16
7.Appendix C Waveforms .....	17
8.Appendix D Visual and dimensional check.....	20

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2022-0041(E) Total 21 Page 2
Client	ANHUI CHARDON ELECTRIC LTD.	Manufacturer	ANHUI CHARDON ELECTRIC LTD.
Object	Separated Connectors 17kV/45kV(17kV/50kV) Coupling(Rear)T-Body Surge Arrester	Type	17-RDTA45/17-FDTA45 (17-RDTA50/17-FDTA50) (Φ32mm×30mm)
Sampling procedure	By the client delivery	Serial No.	1arresters (001) 10 thermally prorated sections (201~210) 13 resistors (301~313) 1 housings(401) 4 dielectrically prorated section(101~104)
Test Category	Type Test	Date	2021.12.31~2022.02.28
Requirements	GB/T 11032-2020 Metal-oxide surge arresters without gaps for a.c. systems		
Conclusion	The Separated connectors 17kV/45kV(17kV/50kV) coupling(Rear)T-Body surge arrester type 17-RDTA45/17-FDTA45 (17-RDTA50/17-FDTA50) have successfully passed the type test specified in GB/T 11032-2020.		
Note	Note :See appendix A for sample instruction.		
Tested by: 万克  梁菊霞 			
Checked by: 王陆璐  Verified by: 左中秋 			
Approved by: 王保山  Date of issue: 2022.03.31			

## Test Results

No.	Item	Requirements	Results	Evaluation	
1	D.C. reference voltage test	$25.0\text{kV} \leq U_{\text{ImADC}} \leq 26.0\text{kV}$	25.6kV	Pass	
2	Leakage current test at 0.75 times D.C. reference voltage	$I_{\text{L}}(0.75U_{\text{ImADC}}) \leq 50\mu\text{A}$	2 $\mu\text{A}$	Pass	
3	Continuous current test	Resistive current $I_{\text{R}} \leq 200\mu\text{A}$ Total current $I_{\text{X}} \leq 1000\mu\text{A}$	$I_{\text{X}}=157\mu\text{A}$ $I_{\text{R}}=25\mu\text{A}$	Pass	
4	Power-frequency reference voltage test	Power-frequency reference voltage of the arrester $\geq 17.0\text{kV}_{\text{p}}/\sqrt{2}$	$18.91\text{kV}_{\text{p}}/\sqrt{2}$	Pass	
5	Internal partial discharge test	$1.05U_{\text{c}}, \text{PD} \leq 10 \text{ pC}$	PD=2.3 pC	Pass	
6	Insulation withstand tests on the arrester housing	Power-frequency voltage: Dry $\geq 42.0\text{kV}$ , for 1min. Lightning impulse voltage : $75\text{kV}_{\text{p}}$ , the positive and negative 15 times respectively.	Power-frequency voltage dry: $42.2\text{kV}_{\text{rms}}$ , 1min. Lightning impulse voltage: $75.8\text{kV}_{\text{p}}\sim 76.9\text{kV}_{\text{p}}$ the positive and negative 15 times respectively.	Pass	
7	Residual voltage test	Lightning impulse	$\leq 45.0\text{kV}_{\text{p}}$	44.70kV <sub>p</sub>	Pass
		Switching impulse	$\leq 38.3\text{kV}_{\text{p}}$	34.57kV <sub>p</sub>	
		Steep current	$\leq 54.0\text{kV}_{\text{p}}$	46.3kV <sub>p</sub>	
8	Repetitive charge transfer withstand test	10 samples should withstand 20 times 8/20 $\mu\text{s}$ lightning impulse current and the charge value should not less than 0.2C.	0.220C ~0.233C	Pass	
9	Test to verify long term stability under continuous operating voltage	The accelerated ageing test of resistors should be carried out according to the specified procedure.	$P_{\text{max}} \leq 1.3P_{\text{min}}$ , $P_{\text{all.max}} \leq 1.1P_{\text{start}}$ ; the samples fulfilled the requirements.	Pass	
10	Heat dissipation behavior verification test	The test section should have a temperature higher than the complete arrester for all instants during the cooling period.	Fulfilled the requirements. See fig 2.	Pass	

11	Operating duty test	Rated thermal charge injection $Q_{th} \geq 0.7 C$ . The residual voltage should not have changed by more than 5%.	$Q_{th} \geq 0.723C$ The residual voltage changed ratio is from -1.51%~-1.32%	Pass
12	Power-frequency voltage-versus-time characteristics	Supply the Power frequency voltage-versus-time characteristics for the range of voltage from $1.20U_r^*$ to $1.00U_r^*$ , the range of time from 0.1s to 1200s for with prior duty, $1.20U_r^*$ to $1.00U_r^*$ , the range of time from 1.1s to 1200s for without prior duty.	With prior duty test $1.20U_r^*$ 0.1s $1.15 U_r^*$ 1.1s $1.10 U_r^*$ 10.1s $1.00 U_r^*$ 1200s  Without prior duty test $1.20U_r^*$ 1.1s $1.00U_r^*$ 1200s	Pass
13	Test to verify the dielectric withstand of the internal components of an	1 time 65kA-4/10 $\mu$ s	65.2kA, no puncture, flashover, cracking or other significant damage.	Pass

(No content in this page below)

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2022-0041(E) Total 21 Page 5
-------------	--	--

**Content:**

**1~2D.C. reference voltage test and leakage current at 0.75 times D.C. reference voltage test**

Environment temperature: 7.0°C humidity: 73%

Samples	D.C. reference voltage $U_{ImADC}$ kV		0.75 times D.C. reference voltage kV		Leakage current $\mu A$	
	Measured value	Specified value	Measured value	Specified value	Measured value	Specified value
001	25.6	$25.0 \leq U_{ImADC} \leq 26.0$	19.2	$0.75U_{ImADC} \pm 1\%$	2	$\leq 50$

Note: The standard only provides the D.C. reference voltage lower limit. The upper limit declared by the manufacturer is used to determine the proportion of the arrester protection level.

Fulfilled the requirements.

**3 Power-frequency reference voltage test**

Sample	$U_{ImAAC}, kV_p / \sqrt{2}$	
	Measured value	Specified value
001	18.91	$\geq 17.0$

Fulfilled the requirements.

**4 Continuous current test**

Sample	Resistive current $I_R \mu A_p$		Full current $I_X \mu A_{rms}$	
	Measured value	Specified value	Measured value	Specified value
001	25	$\leq 200$	157	$\leq 1000$

NOTE: The continuous current of the arrester under the continuous operating voltage declared by manufacturer.

Fulfilled the requirements.

**5 Internal partial discharge test**

Samples	$U_r$	$U_r$ duration time	$1.05U_c$	$1.05U_c$ duration time	Partial discharge
	$kV_{rms}$	s	$kV_{rms}$	s	pC
001	17.1	10	14.3	60	2.3
Specified value	17.0	2~10	14.3	60	$\leq 10$

Fulfilled the requirements.

**6 Insulation withstand tests on the arrester housing****6.1 Power frequency voltage withstand test**

t=8.0°C RH=65% Atmospheric pressure:101.9kPa

Samples	Specified value	Applied voltage	Duration	Test result
	kV <sub>rms</sub>	kV <sub>rms</sub>	s	
401	42.0(dry)	42.2	60	No flashover

Fulfilled the requirements.

**6.2 Lightning impulse voltage withstand test**

t=8.0°C RH=65% Atmospheric pressure:101.9kPa

Samples	Specified value		Applied voltage	Withstand times	Test result
	kV		kV <sub>p</sub>		
401	(+)	75	75.8~76.8	15	No breakdown, no flashover
	(-)	75	76.1~76.9	15	No breakdown, no flashover

Fulfilled the requirements.

(No content in this page below)

**7 Residual voltage test**

**7.1 Lightning impulse current residual voltage test**

Samples			301	302	303
Residual voltage of the sections	$U_{1mAAC}$	kV	6.16	6.16	6.16
	8/20 $\mu$ s, 2.5kA	kV <sub>p</sub>	9.80	9.78	9.80
	8/20 $\mu$ s, 5kA	kV <sub>p</sub>	10.59	10.56	10.58
	8/20 $\mu$ s, 10kA	kV <sub>p</sub>	11.69	11.66	11.67
Residual voltage of the arresters	Ratio, n	-	4.22	4.22	4.22
	8/20 $\mu$ s, 2.5kA	kV <sub>p</sub>	41.36	41.28	41.36
	8/20 $\mu$ s, 5kA	kV <sub>p</sub>	44.70	44.57	44.66
	8/20 $\mu$ s, 10kA	kV <sub>p</sub>	49.34	49.21	49.26
	Lightning impulse protection level	kV <sub>p</sub>	44.70		
	Specified value	kV <sub>p</sub>	$\leq 45.0$		

Note 1: Shunt 0.025 V/A, divider  $K_d=206.8$

Note 2: According to the determined residual pressure, draw the residual voltage and current curve, in the curve corresponding to the nominal discharge current read residual voltage, defined as the lightning protection lightning protection level.

**7.2 Switching impulse residual voltage test**

Samples			301	302	303
Resistor	Residual voltage at 250A	kV <sub>p</sub>	8.19	8.17	8.17
Complete arrester	Test value	kV <sub>p</sub>	34.57	34.48	34.48
	Switching impulse protection level	kV <sub>p</sub>	34.57		
	Specified value	kV <sub>p</sub>	$\leq 38.3$		

Note: Shunt 0.025 V/A, divider  $K_d=206.8$

(No content in this page below)



**7.3 Steep impulse current residual voltage test**

Samples			301	302	303
Residual voltage of the sections	5kA <sub>p</sub> U <sub>res1</sub>	kV <sub>p</sub>	11.18	11.15	11.17
Residual voltage of metal block	5kA <sub>p</sub> U <sub>res2</sub>	kV <sub>p</sub>	0.27		
Residual voltage after correction	U <sub>res1</sub> -U <sub>res2</sub>	kV <sub>p</sub>	10.91	10.88	10.90
Complete arrester	Ratio, n	-	4.22	4.22	4.22
	Residual voltage for the arrester	kV <sub>p</sub>	46.0	45.9	46.0
	inductive voltage drop	kV <sub>p</sub>	0.3kV/m×0.16m×5=0.24kV		
	After correction	kV <sub>p</sub>	46.3	46.2	46.2
	Steep current impulse protection level	kV <sub>p</sub>	46.3		
	Specified value	kV <sub>p</sub>	≤54.0		

Note1: Shunt 0.0267V/A, divider K<sub>d</sub>=59.8。

Note 2: U<sub>res2</sub>/ U<sub>res1</sub> is larger than 2%, need to correct Inductive effect.

Fulfilled the requirements. Test waveform is shown in appendix C fig C.1~ fig C.3.

(No content in this page below)

### 8 Repetitive charge transfer withstand

Samples:10 resistors (304~313)

Requirements of standards: The samples should withstand more than 0.2C by 8/20us current impulse for 20 times, and after test, have no breakdown or flashover or breakage, the change of residual voltage within  $\pm 5\%$ , the change of reference voltage within  $\pm 5\%$ , also should withstand capability to one 8/20us current impulse of at least 0.5 kA/cm<sup>2</sup> peak current density or 2 times In, whichever is lower.

Test data: Fulfilled the requirements , the test waveforms were shown in appendix C fig C.4.

Samples		304	305	306	307	308	309	310	311	312	313
Before test	$U_{1mAAC}$ , kV	4.48	4.47	4.47	4.47	4.47	4.45	4.49	4.47	4.47	4.47
	$8/20\mu s U_{5kAp}$ , kV	10.59	10.57	10.55	10.56	10.57	10.53	10.59	10.55	10.56	10.56
$Q_{rs}$ , C		$Q_{rs}$ (Claimed repetitive charge transfer rating) $\times 1.1=0.22$									
1 <sup>st</sup>	$Q_{rs}$ , C	0.226	0.220	0.230	0.224	0.221	0.230	0.224	0.231	0.226	0.231
2 <sup>nd</sup>	$Q_{rs}$ , C	0.228	0.230	0.222	0.232	0.226	0.226	0.227	0.223	0.231	0.224
3 <sup>rd</sup>	$Q_{rs}$ , C	0.224	0.228	0.227	0.231	0.226	0.230	0.225	0.221	0.226	0.221
4 <sup>th</sup>	$Q_{rs}$ , C	0.226	0.231	0.225	0.232	0.225	0.223	0.230	0.233	0.221	0.230
5 <sup>th</sup>	$Q_{rs}$ , C	0.225	0.226	0.220	0.226	0.223	0.231	0.224	0.229	0.231	0.227
6 <sup>th</sup>	$Q_{rs}$ , C	0.222	0.228	0.232	0.232	0.224	0.230	0.229	0.232	0.222	0.229
7 <sup>th</sup>	$Q_{rs}$ , C	0.222	0.228	0.232	0.221	0.225	0.225	0.228	0.231	0.231	0.232
8 <sup>th</sup>	$Q_{rs}$ , C	0.226	0.231	0.232	0.220	0.222	0.233	0.227	0.227	0.224	0.232
9 <sup>th</sup>	$Q_{rs}$ , C	0.225	0.225	0.225	0.229	0.230	0.224	0.226	0.223	0.224	0.221
10 <sup>th</sup>	$Q_{rs}$ , C	0.220	0.221	0.229	0.232	0.222	0.227	0.228	0.228	0.229	0.224
11 <sup>th</sup>	$Q_{rs}$ , C	0.222	0.224	0.229	0.225	0.229	0.220	0.230	0.228	0.231	0.222
12 <sup>th</sup>	$Q_{rs}$ , C	0.223	0.226	0.221	0.230	0.224	0.222	0.227	0.229	0.226	0.222
13 <sup>th</sup>	$Q_{rs}$ , C	0.223	0.221	0.230	0.222	0.233	0.231	0.226	0.222	0.232	0.231
14 <sup>th</sup>	$Q_{rs}$ , C	0.223	0.233	0.223	0.228	0.229	0.228	0.223	0.228	0.223	0.224
15 <sup>th</sup>	$Q_{rs}$ , C	0.225	0.222	0.224	0.223	0.230	0.232	0.223	0.233	0.222	0.231
16 <sup>th</sup>	$Q_{rs}$ , C	0.225	0.232	0.226	0.226	0.227	0.224	0.224	0.221	0.225	0.231
17 <sup>th</sup>	$Q_{rs}$ , C	0.223	0.229	0.220	0.228	0.226	0.224	0.221	0.230	0.223	0.227
18 <sup>th</sup>	$Q_{rs}$ , C	0.231	0.231	0.226	0.221	0.228	0.226	0.226	0.221	0.232	0.231
19 <sup>th</sup>	$Q_{rs}$ , C	0.222	0.226	0.229	0.228	0.224	0.224	0.227	0.221	0.226	0.222
20 <sup>th</sup>	$Q_{rs}$ , C	0.229	0.225	0.221	0.221	0.228	0.224	0.228	0.223	0.232	0.229

Test evaluation	One 8/20 current impulse, kA	4.02 kA $(0.5\text{kA}/\text{cm}^2=0.5 \times 3.14 \times (3.2/2)^2=4.02\text{kA}$ which is lower than 2 times $I_n$ )									
	$U_{1mAAC}$ , kV	4.05	4.06	4.05	4.05	4.06	4.07	4.06	4.06	4.05	4.06
	Change rate, %	4.42	4.41	4.42	4.39	4.38	4.39	4.38	4.37	4.39	4.38
	8/20 $\mu$ s $U_{5kAp}$ , kV	-1.34	-1.34	-1.12	-1.79	-2.01	-1.35	-2.45	-2.24	-1.09	-2.01
	Change rate, %	10.72	10.71	10.75	10.73	10.71	10.72	10.82	10.81	10.78	10.78
	Visual inspection	+1.23	+1.32	+1.90	+1.61	+1.32	+1.80	+2.17	+2.46	+2.08	+2.08
	All the samples have no puncture, flashover or cracking.										

### 9 Test to verify long term stability under continuous operating voltage

Samples: 3 dielectrically prorated sections(101~103)

Requirements of standards: 3 resistors should pass the accelerated ageing test.

Test data: Fulfilled the requirements, the accelerated ageing curves were shown in fig 1.

Samples	101	102	103
$U_{1mADC}$ , kV	6.20	6.20	6.18
$U_c$ , kV <sub>rms</sub>	3.37	3.37	3.37
Power losses $P_{start}$ , 3h, W	0.870	0.697	0.775
Power losses $P_{100h}$ , W	0.608	0.487	0.559
Power losses $P_{200h}$ , W	0.589	0.479	0.531
Power losses $P_{300h}$ , W	0.564	0.464	0.525
Power losses $P_{400h}$ , W	0.555	0.457	0.515
Power losses $P_{500h}$ , W	0.563	0.476	0.534
Power losses $P_{600h}$ , W	0.552	0.438	0.512
Power losses $P_{700h}$ , W	0.567	0.427	0.501
Power losses $P_{800h}$ , W	0.560	0.419	0.509
Power losses $P_{900h}$ , W	0.557	0.413	0.486
Power losses $P_{end}$ , 1000+8h, W	0.562	0.421	0.502
$P_{min}$ , W	0.552	0.413	0.486
Any increase of power losses from $P_{min}$ during the remaining test period, $P_{max}$	0.567	0.421	0.502
$P_{all.max}$ , W	0.870	0.697	0.775
$P_{max} / 1.3P_{min}$	0.790	0.784	0.794
$P_{all.max} / 1.1 P_{start}$	0.909	0.910	0.910

Note: (1) Because  $P_{max} \leq 1.3P_{min}$ ,  $P_{all.max} \leq 1.1P_{start}$ , the samples fulfilled the requirements.  
(2) The temperature of blocks:  $115 \pm 4$  °C.




Fig 1 Accelerated ageing test curve

**10 Heat dissipation behavior verification of test sample**

Samples: 1 thermally prorated section (210) 1 arrester (001)

Requirements of standards: the MO resistors in the sample shall be heated to 140°C by the application of power-frequency voltage. When the temperature is reached, the voltage source shall be disconnected and the cooling time curve shall be determined. At any time, the measured cooling curve of section falls shall above the measured cooling curve of the arrester.

Test data: Fulfilled the requirements, the test waveform was shown in fig 2. The operating duty test preheated temperature should be 85°C.




Fig 2 The cooling curve for the section and arrester

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2022-0041(E) Total 21 Page 12		
<b>11 Operating duty test</b>					
Samples: 3 thermally prorated sections (201~203)					
Requirements of standards: 3 thermally prorated sections should pass the high current impulse operating duty test.					
Test data: Fulfilled the requirements, the test waveforms were shown in appendix C fig C.5~C.8.					
Samples		201	202	203	
U <sub>1mADC</sub> , kV		6.17	6.17	6.17	
U <sub>sr</sub> , kV <sub>rms</sub>		4.37	4.37	4.37	
U <sub>sc</sub> , kV <sub>rms</sub>		3.50	3.50	3.50	
8/20μs, U <sub>5kAp</sub> ,before, kV		10.62	10.63	10.62	
Conditioning test	1 <sup>st</sup> high current impulse, kA <sub>p</sub>	65.1	65.2	64.8	
	2 <sup>nd</sup> high current impulse, kA <sub>p</sub>	65.6	64.9	65.2	
preheated samples		preheated samples to 85.0°C±3°C			
Rated thermal charge transfer ,Q <sub>th</sub>	Lightning current impulse	1 <sup>st</sup> Q <sub>th</sub> ,C	0.365	0.368	0.365
		2 <sup>nd</sup> Q <sub>th</sub> ,C	0.358	0.362	0.367
	Q <sub>th</sub> rating (2 times) , C		0.723	0.730	0.732
Applied voltage after the 2 <sup>nd</sup> impulse	Time	Req.	as short as possible (within 100ms)		
		Actual	86	88	84
	Applied voltage and duration	U <sub>sr</sub> *, kV <sub>rms</sub>	4.37	4.37	4.37
		Duration, s	10	10	10
		U <sub>sc</sub> *, kV <sub>rms</sub>	3.50	3.50	3.50
Duration, min		30	30	30	
Power loss, W	1 s		4.52	4.26	4.67
	5 min		2.37	2.28	2.42
	10 min		1.62	1.57	1.69
	15 min		1.35	1.32	1.41
	20 min		1.03	1.01	1.07
	25 min		0.95	0.95	1.02
	30 min		0.94	0.94	1.01
Samples cooled to		cooled to ambient 20°C±15°C			
8/20μs, U <sub>5kAp</sub> ,after, kV		10.47	10.49	10.46	
Variability of the residual voltage, %		-1.41	-1.32	-1.51	
Visual inspection		No puncture, flashover, cracking or other significant damage			
Fulfilled the requirements.					

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment			CEPRI-EETC02-2022-0041(E) Total 21 Page 13		
<b>12 Power-frequency voltage-versus-time test</b>						
<b>12.1 Power-frequency voltage-versus-time test data (with prior duty)</b>						
Samples		204	205	206	207	
U <sub>1mADC</sub> , kV		6.16	6.17	6.17	6.18	
U <sub>sr</sub> , kV <sub>rms</sub>		4.36	4.37	4.37	4.38	
U <sub>sc</sub> , kV <sub>rms</sub>		3.49	3.50	3.50	3.50	
8/20μs, U <sub>5kAp</sub> ,before, kV		10.61	10.63	10.62	10.65	
preheated samples		preheated samples to 85°C±3°C				
2ms long-duration current impulse	1 <sup>st</sup> impulse	Q <sub>th</sub> , C	0.367	0.359	0.366	0.365
	2 <sup>nd</sup> impulse	Q <sub>th</sub> , C	0.358	0.366	0.362	0.367
	Q <sub>th</sub> rating (2 times), C		0.725	0.725	0.728	0.732
Applied voltage after the 3 <sup>rd</sup> impulse	Time	Req.	as short as possible (within 100ms)			
		Actual	86	88	88	84
	Applied voltage and duration	U <sub>sr</sub> <sup>*</sup> , kV <sub>rms</sub>	5.24	5.03	4.81	4.38
		TOV scale	1.20	1.15	1.10	1.00
		Duration, s	0.1	1.10	10.1	1200
		U <sub>sc</sub> <sup>*</sup> , kV <sub>rms</sub>	3.49	3.50	3.50	3.50
	Duration, min	30	30	30	30	
Power loss, W	1 s		10.32	8.13	6.22	4.98
	5 min		7.21	4.28	4.01	2.35
	10 min		5.47	3.12	3.02	1.87
	15 min		4.22	2.35	2.05	1.56
	20 min		3.28	1.65	1.57	1.28
	25 min		2.73	1.32	1.19	1.07
	30 min		2.41	1.16	0.98	0.96
Samples cooled to		cooled to ambient 20°C±15°C				
8/20μs, U <sub>5kAp</sub> ,after, kV		10.47	10.51	10.55	10.73	
Variability of the residual voltage, %		-1.32	-1.13	-0.66	+0.75	
Visual inspection		No puncture, flashover, cracking or other significant				

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2022-0041(E) Total 21 Page 14	
<b>12.2 Power-frequency voltage-versus-time test data (without prior duty):</b>				
Samples		208	2209	
$U_{1mADC}$ , kV		6.18	6.18	
$U_{sr}$ , kV <sub>rms</sub>		4.38	4.38	
$U_{sc}$ , kV <sub>rms</sub>		3.50	3.50	
8/20 $\mu$ s, $U_{5kAp}$ , before, kV		10.67	10.66	
preheated samples		preheated samples to 85.0°C±3°C		
Applied voltage	Applied voltage and duration	$U_{sr}^*$ , kV <sub>rms</sub>	5.25	4.38
		TOV scale	1.20	1.00
		Duration, s	1.1	1200
		$U_{sc}^*$ , kV <sub>rms</sub>	3.50	3.50
		Duration, min	30	30
Power loss, W	1 s	3.22	2.37	
	5 min	1.86	1.66	
	10 min	1.52	1.27	
	15 min	1.22	1.06	
	20 min	1.06	0.99	
	25 min	0.97	0.92	
	30 min	0.96	0.91	
Samples cooled to		cooled to ambient 20°C±15°C		
8/20 $\mu$ s, $U_{5kAp}$ , after, kV		10.72	10.70	
Variability of the residual voltage, %		+0.47	+0.38	
Visual inspection		No puncture, flashover, cracking or other significant damage		
Fulfilled the requirements, the test waveforms were shown in appendix C fig C.9.				

**13 Test to verify the dielectric withstand of the internal components of an arrester**

Samples: 1 dielectrically prorated section (104)

Requirements of standards: preheat the sample to 60°C, consists of one application of a 65kA high-current impulse.

There should be no evidence of a dielectric breakdown. The test waveforms were shown in appendix C fig C.10.

Sample	104	
U <sub>1mAAC</sub> , kV	4.48	
8/20μs, U <sub>5kA</sub> , before, kV	10.59	
preheated samples	preheated samples to 60°C±3°C	
high-current impulse, kA	65.2	
Samples cooled to	cooled to ambient 20°C±15°C	
8/20μs, U <sub>10kA</sub> , after, kV	10.65	
Variability of the residual voltage, %	+0.57	
Visual inspection	The block can not remove from the section	
	8/20μs current impulse, 2 times	4.02 kA (0.5kA/cm <sup>2</sup> =0.5×3.14×(3.2/2) <sup>2</sup> =4.02kA which is lower than 2 times I <sub>n</sub> )
	1 <sup>st</sup> impulse, kA <sub>p</sub>	4.06
	2 <sup>nd</sup> impulse, kA <sub>p</sub>	4.07
	Curve check	No puncture, flashover, cracking or other significant damage

(No content in this page below)



**Appendix A: Object Parameters**Rated voltage  $U_r$ : 17kVContinuous operating voltage  $U_c$ :  $13.6kV_{rms}$ Nominal discharge current  $I_n$ : 5kALightning impulse residual voltage:  $U_{res}$ :  $\leq 45kV_p$ 

Sample instruction:

①1 arrester, number EETC02-21/11/30-0041-001, short for 001 in report; ②10 thermally prorated sections, number EETC02-21/11/30-0041-201~EETC02-21/11/30-0041-210 short for 201~210 in report; ③13 resistors, number EETC02-21/11/30-0041-301~EETC02-21/11/30-0041-313, short for 301~313 in report; ④1 housings, number EETC02-21/11/30-0041-401, short for 401 in report.; ⑤4 dielectrically prorated sections, number EETC02-21/11/30-0041-101~EETC02-21/11/30-0041-104, short for 101~104 in report.

**Appendix B: Main test device**

NO.	Device name	Device NO.	Measurement	Uncertainty /Accuracy	Calibration institution	Expiration date
1	impulse current generator	EETC02-0003	8/20 $\mu s$ 100 kA, 20kV 4/10 $\mu s$ 150 kA, 20kV 30/80 $\mu s$ 50 kA, 20kV	$U_{rel}=0.015 k=2$ $U_{rel}=0.021 k=2$	National center for high voltage measurement	2023-06-23
2	impulse current generator	EETC02-0005	8/20 $\mu s$ 50 kA, 20kV 30/80 $\mu s$ 10 kA, 20kV	$U_{rel}=0.015 k=2$ $U_{rel}=0.018 k=2$	National center for high voltage measurement	2023-06-29
3	Steep current impulse generator	EETC02-0004	1/5 $\mu s$ 20kA , 20kV	$U_{rel}=0.015 k=2$ $U_{rel}=0.018 k=2$	National center for high voltage measurement	2023-06-29
4	800kV impulse voltage generator	EETC02-0007	0~800 kV	$U_{rel}=0.019 k=2$ $U_{rel}=0.016 k=2$	National center for high voltage measurement	2022-05-28
5	400kV DC high voltage generator	EETC02-0008	DC 0~400kV	$U_{rel}=0.012 k=2$	National center for high voltage measurement	2022-08-18
6	Operating duty test system-voltage	EETC02-0009	0~10kV	$U_{rel}=0.006 k=2$	Beijing Aerospace measurement and testing technology institute	2023-01-06
7	JFD-251 PD tester	EETC02-0043	/	$U_{rel}=0.015 k=2$	Beijing Aerospace measurement and testing technology institute	2023-01-04
8	DC reference voltage tester	EETC02-0048	DC 0~9 kV	$U_{rel}=0.008 k=2$	National center for high voltage measurement	2022-05-10
9	Temperature measuring system	EETC02-0053	0~150 $^{\circ}C$	$U_{rel}=0.2^{\circ}C k=2$	Hubei province meteorological metrological verification station	2022-12-05

Appendix C: Waveforms




Fig C.1 Lightning impulse current and residual voltage waveform (sample 301, shunt 0.025V/A, divider  $K_d=206.8$ )




Fig C.2 Switching impulse current and residual voltage waveform (sample 301, shunt 0.025V/A, divider  $K_d=206.8$ )




Fig C.3 Step impulse current and residual voltage waveform (sample 301, shunt 0.0267V/A, divider  $K_d=59.8$ )




Fig C.4 The 1<sup>st</sup> time of sample 304, Repetitive charge transfer withstand, 0.00192V/A




Fig C.5 Operating duty waveform, sample 201,  $K_d=1540$




Fig C.6 Power-frequency voltage-versus-time test waveform, sample 204,  $K_d=1540$




Fig C.7 Power-frequency voltage-versus-time test waveform, sample 205,  $K_d=1540$




Fig C.8 Power-frequency voltage-versus-time test waveform, sample 206,  $K_d=1540$




Fig C.9 Power-frequency voltage-versus-time test waveform, sample 208,  $K_d=1540$




Fig C.10 Test to verify the dielectric withstand of the internal components of an arrester , sample 104

Appendix D: Visual and dimensional check



Fig D1: 17-RDTA45/17-FDTA45 (17-RDTA50/17-FDTA50) type arrester and resistors




Fig D2 : Dimensional drawing of 17-RDTA45/17-FDTA45 (17-RDTA50/17-FDTA50)